

NEPOOL Participants Committee Report

August 2021



Vamsi Chadalavada

EXECUTIVE VICE PRESIDENT AND CHIEF OPERATING OFFICER



Table of Contents

| | | |
|--|------|-----|
| • Highlights | Page | 3 |
| • System Operations | Page | 13 |
| • Market Operations | Page | 26 |
| • Back-Up Detail | Page | 43 |
| – Demand Response | Page | 44 |
| – New Generation | Page | 46 |
| – Forward Capacity Market | Page | 53 |
| – Reliability Costs - Net Commitment Period Compensation (NCPC) Operating Costs | Page | 59 |
| – Regional System Plan (RSP) | Page | 88 |
| – Operable Capacity Analysis – Summer 2021 Analysis | Page | 114 |
| – Operable Capacity Analysis – Preliminary Fall Analysis | Page | 121 |
| – Operable Capacity Analysis – Appendix | Page | 128 |





Regular Operations Report - Highlights



Highlights

- Day-Ahead (DA), Real-Time (RT) Prices and Transactions
 - Update: June 2021 Energy Market value totaled \$478M
 - July 2021 Energy market value was \$427M, down \$51M from June 2021 and up \$100M from July 2020
 - July 2021 natural gas prices over the period were 14% higher than June average values
 - Average RT Hub Locational Marginal Prices (\$36.04/MWh) over the period were 0.6% higher than June averages
 - DA Hub LMP: \$37.59/MWh
 - Average July 2021 natural gas prices and RT Hub LMPs over the period were up 99% and 60%, respectively, from July 2020 averages
 - Average DA cleared physical energy during the peak hours as percent of forecasted load was 100.6% during July, up from 99.1% during June*
 - The minimum value for the month was 96.2% on Sunday, July 4th

All data through July 28th

*DA Cleared Physical Energy is the sum of Generation and Net Imports cleared in the DA Energy Market

Underlying natural gas data furnished by:



Highlights, cont.


- Daily Net Commitment Period Compensation (NCPC)
 - July 2021 NCPC payments totaled \$2.7M over the period, down \$1.2M from June 2021 and up \$0.9M from July 2020
 - First Contingency payments totaled \$2.1M, down \$0.6M from June
 - \$2.1M paid to internal resources, down \$0.3M from June
 - » \$368K charged to DALO, \$1M to RT Deviations, \$661K to RTLO*
 - \$20K paid to resources at external locations, down \$352K from June
 - » \$9K charged to DALO at external locations, \$11K to RT Deviations
 - Second Contingency payments totaled \$331K, down \$850K from June
 - Distribution payments totaled \$276K, up \$245K from June
 - Voltage payments were zero
 - NCPC payments over the period as percent of Energy Market value were 0.6%

* NCPC types reflected in the First Contingency Amount: Dispatch Lost Opportunity Cost (DLOC) - \$194K; Rapid Response Pricing (RRP) Opportunity Cost - \$256K; Posturing - \$210K; Generator Performance Auditing (GPA) - \$0K




Price Responsive Demand (PRD) Energy Market Activity by Month

DA, RT, and RT Dev MWh



Market Value



Note: DA and RT (deviation) MWh are settlement obligations and reflect appropriate gross-ups for distribution losses.



Highlights

- Production cost preliminary results for the 2021 Economic Study (Future Grid Reliability Study) continued to be presented at the July Planning Advisory Committee meeting, with the remaining results expected in September
- FCA 16 Installed Capacity Requirement (ICR) assumptions and results are being discussed at the Power Supply Planning Committee
 - RC to vote on ICR and Related Values at their September 21 meeting
- Regional System Plan development continues and stakeholder comments are due on August 3
 - Public Meeting will be held virtually on October 6
- Four Attachment K revisions are in various stages of development



Forward Capacity Market (FCM) Highlights

- CCP 12 (2021-2022)
 - Third and final annual reconfiguration auction (ARA3) was held on March 1-3, and results were posted on March 29
- CCP 13 (2022-2023)
 - Second annual reconfiguration auction (ARA2) will be held on August 2-4, and results will be posted no later than September 1
- CCP 14 (2023-2024)
 - First annual reconfiguration auction (ARA1) was held on June 1-3, and results were posted June 30
- CCP 15 (2024-2025)
 - Auction results were filed with FERC on February 26 and FERC approved on June 24

CCP – Capacity Commitment Period



FCM Highlights, cont.

- CCP 16 (2025-2026)
 - FCA 16 will model the same zones as FCA 15
 - Export-constrained zones: Northern New England and Maine nested inside Northern New England
 - Import-constrained zones: Southeast New England
 - New Capacity Qualification Package (NCQP) submission window closed on June 18, and review of the NCQPs is ongoing
 - ICR and Related Values development continues and discussions regarding assumptions and results are being held at the PSPC; on track for an RC vote in September



Load Forecast

- Efforts continue to enhance load forecast models and tools to improve day-ahead and long-term load forecast performance
- Continuing to evaluate the impacts of COVID-19 to the load forecast



Competitive Solution Process: Order 1000/Boston 2028 Request for Proposal Lessons Learned

- The ISO began one-on-one discussions with each QTPS that participated in the Boston 2028 RFP where QTPS specific questions regarding their proposals and/or the process can be discussed
- The lessons-learned process, with respect to competitive transmission solutions, was discussed at the October PAC meeting
- Stakeholder feedback was discussed at the 12/16/20 PAC meeting, and initial ISO responses were discussed at the 2/17/21 PAC meeting
- At the 4/14/21 PAC meeting, the ISO provided its plans for the remaining open items
- On 5/3/21, the ISO issued a memo to the PAC summarizing next steps in the process
- The ISO held its first discussion on the associated Tariff changes at the 7/14/21 TC meeting. The next discussion is scheduled for the 8/24/21 TC meeting.

Highlights

- The lowest 50/50 and 90/10 Summer Operable Capacity Margins are projected for week beginning September 11, 2021.
- The lowest 50/50 and 90/10 Preliminary Fall Operable Capacity Margins are projected for week beginning September 25, 2021.



SYSTEM OPERATIONS



System Operations

| | | | | |
|-------------------------|--------|--|----------|--|
| <u>Weather Patterns</u> | Boston | Temperature: Below Normal (1.7°F) Max: 95°F, Min: 57°F Precipitation: 10.07" – Above Normal Normal: 3.27" | Hartford | Temperature: Below Normal (1.3°F) Max: 93°F, Min: 52°F Precipitation: 10.15" - Above Normal Normal: 4.17" |
|-------------------------|--------|--|----------|--|

| | | | |
|-------------------|-----------|-----------|----------------|
| <u>Peak Load:</u> | 22,354 MW | 7/16/2021 | 18:00 (ending) |
|-------------------|-----------|-----------|----------------|

Emergency Procedure Events (OP-4, M/LCC 2, Minimum Generation Emergency)

| Procedure | Declared | Cancelled | Note |
|-----------|----------------|----------------|----------------|
| M/LCC 2 | 7/8/2021 17:00 | 7/9/2021 11:00 | Severe Weather |



System Operations


NPCC Simultaneous Activation of Reserve Events

| Date | Area | MW Lost |
|-----------|--------|---------|
| 7/8/2021 | NYISO | 530 |
| 7/16/2021 | ISO-NE | 650 |



2021 System Operations - Load Forecast Accuracy


Dashboard Indicator 



| Month | J | F | M | A | M | J | J | A | S | O | N | D | |
|---------|------|------|------|------|------|------|------|---|---|---|---|---|------|
| Day Max | 4.04 | 4.03 | 3.67 | 5.85 | 3.92 | 5.41 | 7.75 | | | | | | 7.75 |
| Day Min | 0.70 | 0.92 | 0.49 | 0.88 | 0.77 | 0.73 | 0.63 | | | | | | 0.49 |
| MAPE | 1.72 | 1.66 | 1.97 | 2.24 | 1.95 | 2.50 | 2.61 | | | | | | 2.10 |
| Goal | 1.80 | 1.80 | 1.80 | 1.80 | 2.00 | 2.60 | 2.60 | | | | | | |

2021 System Operations - Load Forecast Accuracy cont.

Dashboard Indicator 




| Month | J | F | M | A | M | J | J | A | S | O | N | D | |
|---------|------|------|------|------|------|-------|-------|---|---|---|---|---|-------|
| Day Max | 3.61 | 3.03 | 4.47 | 5.19 | 5.31 | 11.76 | 10.75 | | | | | | 11.76 |
| Day Min | 0.02 | 0.06 | 0.08 | 0.03 | 0.11 | 0.04 | 0.05 | | | | | | 0.02 |
| MAPE | 1.26 | 1.18 | 1.48 | 1.66 | 1.60 | 2.79 | 2.78 | | | | | | 1.83 |
| Goal | 1.80 | 1.80 | 1.80 | 1.80 | 2.00 | 2.60 | 2.60 | | | | | | |

2021 System Operations - Load Forecast Accuracy cont.


Percent of Hours Actual Load
 Above vs. Below Forecast
 Based on LF published by 1000, day before Operating Day

Target = 50%
 Plus/Minus = 5%



| | J | F | M | A | M | J | J | A | S | O | N | D | Avg |
|-----------|--------|--------|--------|--------|--------|--------|--------|---|---|---|---|---|------|
| Above % | 57.1 | 50.4 | 55.6 | 54.4 | 52.8 | 50.3 | 46.9 | | | | | | 53 |
| Below % | 42.9 | 49.6 | 44.4 | 45.6 | 47.2 | 49.7 | 53.1 | | | | | | 47 |
| Avg Above | 209.5 | 166.7 | 185.4 | 206.1 | 227.4 | 233.1 | 214.6 | | | | | | 233 |
| Avg Below | -147.6 | -216.4 | -188.0 | -167.9 | -146.8 | -309.1 | -348.1 | | | | | | -348 |
| Avg All | 60 | -25 | 30 | 40 | 61 | -48 | -122 | | | | | | 0 |


2021 System Operations - Load Forecast Accuracy cont.




Monthly Recorded Net Energy for Load (NEL) and Weather Normalized NEL

Net Energy for Load (NEL)

Weather Normalized NEL



Ann Tot (TWh): 123.5 119.2 116.9 67.6




Ann Tot (TWh): 120.6 118.8 116.3 57.2

NEPOOL NEL is the total net revenue quality metered energy required to serve load and is analogous to 'RT system load.' NEL is calculated as: Generation – pumping load + net interchange where imports are positively signed. Current month's data may be preliminary. Weather normalized NEL may be reported on a one-month lag.




Monthly Peak Loads and Weather Normalized Seasonal Peak History

System Peak Load



Revenue quality metered value

Weather Normalized Seasonal Peaks




Winter beginning in year displayed

F – designates forecasted values, which are typically updated in April/May of the following year; represents “net forecast” (i.e., the gross forecast net of passive demand response and behind-the-meter solar demand)



Wind Power Forecast Error Statistics: Medium and Long Term Forecasts MAE

Rolling 30-day MAE for ISO Wind Power Forecast, as of August 01, 2021




Dashboard Indicator 

Yearly Fleet
Performance targets 

Ideally, MAE and Bias would be both equal to zero. As is typical, MAE increases with the forecast horizon. MAE and Bias for the fleet of wind power resources are less due to offsetting errors. Across all time frames, the ISO-NE/DNV forecast is very good compared to industry standards, and monthly MAE is within the yearly performance targets.

Wind Power Forecast Error Statistics: Medium and Long Term Forecasts Bias

Rolling 30-day Bias for ISO Wind Power Forecast, as of August 01, 2021




Dashboard Indicator ●

Yearly Fleet Performance targets —


Ideally, MAE and Bias would be both equal to zero. Positive bias means less windpower was actually available compared to forecast. Negative bias means more windpower was actually available compared to forecast. Across all time frames, the ISO-NE/DNV forecast compares well with industry standards, and except for the 91 hour lookahead horizon, monthly Bias is within yearly performance targets.

Wind Power Forecast Error Statistics: Short Term Forecast MAE

Rolling 30-day MAE for ISO Wind Power Forecast, as of August 01, 2021




Dashboard Indicator 

Yearly Fleet
Performance targets 

Ideally, MAE and Bias would be both equal to zero. As is typical, MAE increases with the forecast horizon. MAE and Bias for the fleet of wind power resources are less due to offsetting errors. Across all time frames, the ISO-NE/DNV forecast is very good compared to industry standards, and monthly MAE is within the yearly performance targets.

Wind Power Forecast Error Statistics: Short Term Forecast Bias



Dashboard Indicator


Yearly Fleet Performance targets

Ideally, MAE and Bias would be both equal to zero. Positive bias means less windpower was actually available compared to forecast. Negative bias means more windpower was actually available compared to forecast. Across all time frames, the ISO-NE/DNV forecast compares well with industry standards, and monthly Bias is within yearly performance.

MARKET OPERATIONS



Daily Average DA and RT ISO-NE Hub Prices and Input Fuel Prices: July 1-28, 2021




Underlying natural gas data furnished by:




Average price difference over this period (DA-RT): \$1.55
 Average price difference over this period ABS(DA-RT): \$6.47
 Average percentage difference over this period ABS(DA-RT)/RT Average LMP: 18%
 Gas price is average of Massachusetts delivery points

DA LMPs Average by Zone & Hub, July 2021



RT LMPs Average by Zone & Hub, July 2021





Definitions

| Day-Ahead Concept | Definition |
|---|---|
| Day-Ahead Load Obligation (DALO) | The sum of day-ahead cleared load (including asset load, pump load, exports, and virtual purchases and excluding modeled transmission losses) |
| Day-Ahead Cleared Physical Energy | The sum of day-ahead cleared generation and cleared net imports |



Components of Cleared DA Supply and Demand

– Last Three Months




Gen – Generation
 Incs – Increment Offers
 DA Fcst Load – Day-Ahead Forecast Load
 DRR – Demand Response Resource

Fixed Dem – Fixed Demand
 PrSens Dem – Price Sensitive Demand
 Decs – Decrement Bids
 Act Load – Actual Load




Components of RT Supply and Demand – Last Three Months



Supply



Demand




DAM Volumes as % of RT Actual Load (Forecasted Peak Hour)




Note: Forecasted peak hour for each day is reflected in the above values. Shown for each day (chart on right) and then averaged for each month (chart on left). 'DA Bid' categories reflect load assets only (Virtual and export bids not reflected.)

DA vs. RT Load Obligation: July, This Year vs. Last Year

Monthly, Last 13 Months




Daily, This Year vs. Last Year




*Hourly average values

DA Volumes as % of Forecast in Peak Hour

Monthly, Last 13 Months




Daily: This Month



Note: There were **no** instances of system-level manual supplemental commitments for capacity required during the Reserve Adequacy Assessment (RAA) during July.


DA Cleared Physical Energy Difference from RT System Load at Forecasted Peak Hour*




*Negative values indicate DA Cleared Physical Energy value below its RT counterpart. Forecast peak hour reflected.

DA vs. RT Net Interchange July 2020 vs. July 2021

Hourly Average by Day, Last Year




Hourly Average by Day, This Year



Net Interchange is the sum of daily imports minus the sum of daily exports
Positive values are net imports

Variable Production Cost of Natural Gas: Monthly




Note: Assumes proxy heat rate of 7,800,000 Btu/MWh for natural gas units.

Underlying natural gas data furnished by:



Variable Production Cost of Natural Gas: Daily




Note: Assumes proxy heat rate of 7,800,000 Btu/MWh for natural gas units.

Underlying natural gas data furnished by:




Hourly DA LMPs, July 1-28, 2021

Hourly Day-Ahead LMPs




Hourly RT LMPs, July 1-28, 2021

Hourly Real-Time LMPs



System Unit Availability



| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | YTD |
|-------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 2021 | 94 | 94 | 90 | 81 | 84 | 92 | 93 | | | | | | 90 |
| 2020 | 95 | 96 | 93 | 85 | 86 | 91 | 95 | 97 | 91 | 74 | 80 | 89 | 89 |
| 2019 | 95 | 95 | 91 | 81 | 83 | 93 | 95 | 97 | 93 | 81 | 83 | 92 | 90 |

Data as of 7/26/2021

BACK-UP DETAIL



DEMAND RESPONSE



Capacity Supply Obligation (CSO) MW by Demand Resource Type for August 2021

| Load Zone | ADCR* | On Peak | Seasonal Peak | Total |
|--------------|--------------|----------------|---------------|----------------|
| ME | 85.4 | 202.5 | 0.0 | 287.9 |
| NH | 42.1 | 147.6 | 0.0 | 189.7 |
| VT | 43.8 | 125.6 | 0.0 | 169.3 |
| CT | 134.8 | 132.6 | 614.8 | 882.2 |
| RI | 39.2 | 323.4 | 0.0 | 362.6 |
| SEMA | 44.6 | 505.9 | 0.0 | 550.5 |
| WCMA | 91.0 | 539.8 | 39.6 | 670.3 |
| NEMA | 61.7 | 861.1 | 0.0 | 922.8 |
| Total | 542.5 | 2,838.3 | 654.4 | 4,035.3 |

* Active Demand Capacity Resources
 NOTE: CSO values include T&D loss factor (8%).



NEW GENERATION




New Generation Update

Based on Queue as of 7/30/21

- Five new projects totaling 410 MW applied for interconnection study since the last update
 - They consist of two battery, one wind and two solar projects with in-service dates ranging from 2022 to 2024
- One project went commercial and two projects were withdrawn
- In total, 292 generation projects are currently being tracked by the ISO, totaling approximately 31,884 MW



Actual and Projected Annual Capacity Additions By Supply Fuel Type and Demand Resource Type



| | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | Total MW | % of Total ¹ |
|------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|-------------------------|
| Other Renewables | 48 | 142 | 0 | 0 | 0 | 0 | 0 | 190 | 0.6 |
| Battery | 34 | 347 | 2,294 | 1,354 | 2,140 | 0 | 0 | 6,169 | 18.9 |
| Solar ² | 1,878 | 1,232 | 820 | 721 | 150 | 83 | 0 | 4,884 | 15.0 |
| Wind | 19 | 20 | 3,367 | 852 | 5,287 | 3,200 | 6,972 | 19,717 | 60.5 |
| Natural Gas/Oil ³ | 76 | 89 | 23 | 672 | 0 | 0 | 0 | 860 | 2.6 |
| Natural Gas | 53 | 11 | 0 | 0 | 0 | 0 | 0 | 64 | 0.2 |
| Demand Response - Passive | 184 | 380 | -28 | -114 | 0 | 0 | 0 | 422 | 1.3 |
| Demand Response - Active | 204 | 62 | -94 | 86 | 0 | 0 | 0 | 258 | 0.8 |
| Totals | 2,496 | 2,283 | 6,382 | 3,571 | 7,577 | 3,283 | 6,972 | 32,564 | 100.0 |


¹ Sum may not equal 100% due to rounding

² This category includes both solar-only, and co-located solar and battery projects

³ The projects in this category are dual fuel, with either gas or oil as the primary fuel

• DR reflects changes from the initial FCM Capacity Supply Obligations in 2010-11

Actual and Projected Annual Generator Capacity Additions By State



| | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | Total MW | % of Total ¹ |
|---------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|-------------------------|
| Vermont | 15 | 40 | 0 | 50 | 0 | 0 | 0 | 105 | 0.3 |
| Rhode Island | 466 | 160 | 931 | 0 | 0 | 0 | 0 | 1,557 | 4.9 |
| New Hampshire | 30 | 281 | 164 | 20 | 150 | 0 | 0 | 645 | 2.0 |
| Maine | 596 | 523 | 919 | 652 | 0 | 0 | 0 | 2,690 | 8.4 |
| Massachusetts | 888 | 513 | 3,178 | 2,145 | 6,022 | 2,000 | 4,572 | 19,318 | 60.6 |
| Connecticut | 113 | 324 | 1,312 | 732 | 1,405 | 1,283 | 2,400 | 7,569 | 23.7 |
| Totals | 2,108 | 1,841 | 6,504 | 3,599 | 7,577 | 3,283 | 6,972 | 31,884 | 100.0 |

¹ Sum may not equal 100% due to rounding



New Generation Projection

By Fuel Type

| Unit Type | Total | | Green | | Yellow | |
|--------------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Biomass/Wood Waste | 0 | 0 | 0 | 0 | 0 | 0 |
| Battery Storage | 35 | 6,169 | 0 | 0 | 35 | 6,169 |
| Fuel Cell | 4 | 54 | 1 | 10 | 3 | 44 |
| Hydro | 3 | 99 | 2 | 71 | 1 | 28 |
| Natural Gas | 7 | 64 | 0 | 0 | 7 | 64 |
| Natural Gas/Oil | 7 | 860 | 1 | 14 | 6 | 846 |
| Nuclear | 1 | 37 | 0 | 0 | 1 | 37 |
| Solar | 207 | 4,884 | 20 | 336 | 187 | 4,548 |
| Wind | 28 | 19,717 | 1 | 15 | 27 | 19,702 |
| Total | 292 | 31,884 | 25 | 446 | 267 | 31,438 |

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel
- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications

New Generation Projection

By Operating Type

| Operating Type | Total | | Green | | Yellow | |
|----------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Baseload | 7 | 124 | 2 | 15 | 5 | 109 |
| Intermediate | 9 | 822 | 1 | 14 | 8 | 808 |
| Peaker | 248 | 11,221 | 21 | 402 | 227 | 10,819 |
| Wind Turbine | 28 | 19,717 | 1 | 15 | 27 | 19,702 |
| Total | 292 | 31,884 | 25 | 446 | 267 | 31,438 |

- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications

New Generation Projection

By Operating Type and Fuel Type

| Unit Type | Total | | Baseload | | Intermediate | | Peaker | | Wind Turbine | |
|--------------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Biomass/Wood Waste | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Battery Storage | 35 | 6,169 | 0 | 0 | 0 | 0 | 35 | 6,169 | 0 | 0 |
| Fuel Cell | 4 | 54 | 4 | 54 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hydro | 3 | 99 | 2 | 33 | 0 | 0 | 1 | 66 | 0 | 0 |
| Natural Gas | 7 | 64 | 0 | 0 | 4 | 47 | 3 | 17 | 0 | 0 |
| Natural Gas/Oil | 7 | 860 | 0 | 0 | 5 | 775 | 2 | 85 | 0 | 0 |
| Nuclear | 1 | 37 | 1 | 37 | 0 | 0 | 0 | 0 | 0 | 0 |
| Solar | 207 | 4,884 | 0 | 0 | 0 | 0 | 207 | 4,884 | 0 | 0 |
| Wind | 28 | 19,717 | 0 | 0 | 0 | 0 | 0 | 0 | 28 | 19,717 |
| Total | 292 | 31,884 | 7 | 124 | 9 | 822 | 248 | 11,221 | 28 | 19,717 |

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel



FORWARD CAPACITY MARKET



Capacity Supply Obligation (CSO) FCA 12

| Resource Type | Resource Type | FCA | ARA 1 | | ARA 2 | | ARA 3 | |
|------------------------|------------------|------------------|-------------------|---------------|-------------------|-----------------|-------------------|----------------|
| | | CSO | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 624.445 | 659.137 | 34.692 | 603.776 | -55.361 | 587.270 | -16.506 |
| | Passive Demand | 2,975.36 | 3,045.073 | 69.713 | 3,123.232 | 78.159 | 3,322.722 | 199.490 |
| Demand Total | | 3,599.81 | 3,704.21 | 104.4 | 3,727.008 | 22.798 | 3,909.992 | 182.984 |
| Generator | Non-Intermittent | 29,130.75 | 29,244.404 | 113.654 | 28,620.245 | -624.159 | 28,941.276 | 321.031 |
| | Intermittent | 880.317 | 806.609 | -73.708 | 660.932 | -145.677 | 663.179 | 2.247 |
| Generator Total | | 30,011.07 | 30,051.013 | 39.943 | 29,281.177 | -769.836 | 29,604.455 | 323.278 |
| Import Total | | 1,217 | 1,305.487 | 88.487 | 1,307.587 | 2.10 | 1207.78 | -99.807 |
| Grand Total* | | 34,827.88 | 35,060.710 | 232.83 | 34,315.772 | -744.94 | 34,722.227 | 406.455 |
| Net ICR (NICR) | | 33,725 | 33,550 | -175 | 32,230 | -1,320 | 32,925 | 695 |

* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.

ARA – Annual Reconfiguration Auction
 FCA – Forward Capacity Auction
 ICR – Installed Capacity Requirement



Capacity Supply Obligation FCA 13

| Resource Type | Resource Type | FCA | ARA 1 | | ARA 2 | | ARA 3 | |
|------------------------|-------------------------|-------------------|-------------------|----------------|-------|--------|-------|--------|
| | | CSO | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW |
| Demand | <i>Active Demand</i> | 685.554 | 683.116 | -2.438 | | | | |
| | <i>Passive Demand</i> | 3,354.69 | 3,407.507 | 52.817 | | | | |
| Demand Total | | 4,040.244 | 4,090.623 | 50.38 | | | | |
| Generator | <i>Non-Intermittent</i> | 28,586.498 | 27,868.341 | -718.157 | | | | |
| | <i>Intermittent</i> | 1,024.792 | 901.672 | -123.12 | | | | |
| Generator Total | | 2,961.29 | 28,770.013 | -841.28 | | | | |
| Import Total | | 1,187.69 | 1,292.41 | 104.72 | | | | |
| Grand Total* | | 34,839.224 | 34,153.046 | -686.18 | | | | |
| Net ICR (NICR) | | 33,750 | 32,465 | -1,285 | | | | |

* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.



Capacity Supply Obligation FCA 14

| Resource Type | Resource Type | FCA | ARA 1 | | ARA 2 | | ARA 3 | |
|------------------------|------------------|-------------------|-------------------|----------------|-------|--------|-------|--------|
| | | CSO | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 592.043 | 688.07 | 96.027 | | | | |
| | Passive Demand | 3,327.071 | 3,327.932 | 0.861 | | | | |
| Demand Total | | 3,919.114 | 4,016.002 | 96.888 | | | | |
| Generator | Non-Intermittent | 27,816.902 | 28,275.143 | 458.241 | | | | |
| | Intermittent | 1,160.916 | 1,128.446 | -32.47 | | | | |
| Generator Total | | 28,977.818 | 29,403.589 | 425.771 | | | | |
| Import Total | | 1,058.72 | 1,058.72 | 0 | | | | |
| Grand Total* | | 33,955.652 | 34,478.311 | 522.661 | | | | |
| Net ICR (NICR) | | 32,490 | 32,980 | 490 | | | | |

* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.



Capacity Supply Obligation FCA 15

| Resource Type | Resource Type | FCA | ARA 1 | | ARA 2 | | ARA 3 | |
|-----------------|------------------|-------------------|-------|--------|-------|--------|-------|--------|
| | | CSO | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 677.673 | | | | | | |
| | Passive Demand | 3,212.865 | | | | | | |
| Demand Total | | 3,890.538 | | | | | | |
| Generator | Non-Intermittent | 28,154.203 | | | | | | |
| | Intermittent | 1,089.265 | | | | | | |
| Generator Total | | 29,243.468 | | | | | | |
| Import Total | | 1,487.059 | | | | | | |
| Grand Total* | | 34,621.065 | | | | | | |
| Net ICR (NICR) | | 33,270 | | | | | | |

* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.



Active/Passive Demand Response

CSO Totals by Commitment Period

| Commitment Period | Active/Passive | Existing | New | Grand Total |
|-------------------|--------------------|------------------|----------------|------------------|
| 2019-20 | Active | 357.221 | 20.304 | 377.525 |
| | Passive | 2,018.20 | 350.43 | 2,368.63 |
| | Grand Total | 2375.422 | 370.734 | 2746.156 |
| 2020-21 | Active | 334.634 | 85.294 | 419.928 |
| | Passive | 2,236.73 | 554.292 | 2,791.02 |
| | Grand Total | 2571.361 | 639.586 | 3210.947 |
| 2021-22 | Active | 480.941 | 143.504 | 624.445 |
| | Passive | 2,604.79 | 370.568 | 2,975.36 |
| | Grand Total | 3085.734 | 514.072 | 3599.806 |
| 2022-23 | Active | 598.376 | 87.178 | 685.554 |
| | Passive | 2,788.33 | 566.363 | 3,354.69 |
| | Grand Total | 3386.703 | 653.541 | 4040.244 |
| 2023-24 | Active | 560.55 | 31.493 | 592.043 |
| | Passive | 3,035.51 | 291.565 | 3,327.07 |
| | Grand Total | 3596.056 | 323.058 | 3919.114 |
| 2024-25 | Active | 674.153 | 3.520 | 677.673 |
| | Passive | 3,046.064 | 166.801 | 3,212.865 |
| | Grand Total | 3,720.217 | 170.321 | 3,890.538 |

RELIABILITY COSTS – NET COMMITMENT PERIOD COMPENSATION (NCPC) OPERATING COSTS



What are Daily NCPC Payments?

- Payments made to resources whose commitment and dispatch by ISO-NE resulted in a shortfall between the resource's offered value in the Energy and Regulation Markets and the revenue earned from output during the day
- Typically, this is the result of some out-of-merit operation of resources occurring in order to protect the overall resource adequacy and transmission security of specific locations or of the entire control area
- NCPC payments are intended to make a resource that follows the ISO's operating instructions "no worse off" financially than the best alternative generation schedule



Definitions

| | |
|--|---|
| 1 st Contingency NCPC Payments | Reliability costs paid to eligible resources that are providing first contingency (1stC) protection (including low voltage, system operating reserve, and load serving) either system-wide or locally |
| 2 nd Contingency NCPC Payments | Reliability costs paid to resources providing capacity in constrained areas to respond to a local second contingency. They are committed based on 2 nd Contingency (2ndC) protocols, and are also known as Local Second Contingency Protection Resources (LSCPR) |
| Voltage NCPC Payments | Reliability costs paid to resources operated by ISO-NE to provide voltage support or control in specific locations |
| Distribution NCPC Payments | Reliability costs paid to units dispatched at the request of local transmission providers for purpose of managing constraints on the low voltage (distribution) system. These requirements are not modeled in the DA Market software |
| OATT | Open Access Transmission Tariff |




Charge Allocation Key


| Allocation Category | Market / OATT | Allocation |
|---|---------------|---|
| System 1 st Contingency | Market | DA 1 st C (excluding at external nodes) is allocated to system DALO. RT 1 st C (at all locations) is allocated to System 'Daily Deviations'. Daily Deviations = sum of(generator deviations, load deviations, generation obligation deviations at external nodes, increment offer deviations) |
| External DA 1 st Contingency | Market | DA 1 st C at external nodes (from imports, exports, Incs and Decs) are allocated to activity at the specific external node or interface involved |
| Zonal 2 nd Contingency | Market | DA and RT 2 nd C NCPC are allocated to load obligation in the Reliability Region (zone) served |
| System Low Voltage | OATT | (Low) Voltage Support NCPC is allocated to system Regional Network Load and Open Access Same-Time Information Service (OASIS) reservations |
| Zonal High Voltage | OATT | High Voltage Control NCPC is allocated to zonal Regional Network Load |
| Distribution - PTO | OATT | Distribution NCPC is allocated to the specific Participant Transmission Owner (PTO) requesting the service |
| System – Other | Market | Includes GPA, Economic Generator/DARD Posturing, Dispatch Lost Opportunity Cost (DLOC), and Rapid Response Pricing (RRP) Opportunity Cost NCPC (allocated to RTLO); and Min Generation Emergency NCPC (allocated to RTGO). |

Year-Over-Year Total NCPC Dollars and Energy

NCPC Dollars





NCPC Energy*



* NCPC Energy GWh reflect the DA and/or RT economic minimum loadings of all units receiving DA or RT NCPC credits (except for DLOC, RRP, or posturing NCPC), assessed during hours in which they are NCPC-eligible. Scheduled MW for external transactions receiving NCPC are also reflected. All NCPC components (1st Contingency, 2nd Contingency, Voltage, and RT Distribution) are reflected.




DA and RT NCPC Charges




NCPC Charges by Type

Jul-21 Total = \$2.68 M



1st C 2nd C
 Distrib

Last 13 Months




1st C 2nd C
 Voltage Distrib



1st C – First Contingency
 2nd C – Second Contingency
 Distrib – Distribution
 Voltage – Voltage



Daily NCPC Charges by Type





NCPC Charges by Allocation



Note: 'System Other' includes, as applicable: Resource Economic Posturing, GPA, Min Gen Emergency, Dispatch Lost Opportunity Cost (DLOC), and Rapid Response Pricing (RRP) Opportunity Cost credits.


RT First Contingency Charges by Deviation Type



DRR – Demand Response Resource deviations
 Gen – Generator deviations
 Inc – Increment Offer deviations
 Import – Import deviations
 Load – Load obligation deviations




LSCPR Charges by Reliability Region




CT – Connecticut Region
 ME – Maine Region
 NH – New Hampshire Region
 RI – Rhode Island Region
 VT – Vermont Region
 SEMA – Southeast Massachusetts Region
 WCMA – Western/Central Massachusetts Region
 NEMA – Northeast Massachusetts Region

NCPC Charges for Voltage Support and High Voltage Control




NCPC Charges by Type




NCPC Charges as Percent of Energy Market

NCPC By Type as Percent of Energy Market




First Contingency NCPC Charges

Value of Charges



% of Energy Market Value




Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market




Second Contingency NCPC Charges

Value of Charges



% of Energy Market Value




Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market




Voltage and Distribution NCPC Charges

Value of Charges



% of Energy Market Value



Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market



DA vs. RT Pricing

The following slides outline:

- This month vs. prior year's average LMPs and fuel costs
- Reserve Market results
- DA cleared load vs. RT load
- Zonal and total incs and decs
- Self-schedules
- DA vs. RT net interchange




DA vs. RT LMPs (\$/MWh)

| Year 2019 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
|------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Day-Ahead | \$31.54 | \$30.72 | \$30.76 | \$31.20 | \$30.67 | \$31.19 | \$31.51 | \$31.24 | \$31.22 |
| Real-Time | \$30.92 | \$30.26 | \$30.12 | \$30.70 | \$30.05 | \$30.61 | \$30.80 | \$30.68 | \$30.67 |
| RT Delta % | -2.0% | -1.5% | -2.1% | -1.6% | -2.0% | -1.9% | -2.2% | -1.8% | -1.8% |
| Year 2020 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Day-Ahead | \$23.62 | \$22.59 | \$23.27 | \$23.50 | \$22.76 | \$23.27 | \$23.57 | \$23.30 | \$23.32 |
| Real-Time | \$23.62 | \$22.91 | \$23.23 | \$23.54 | \$22.90 | \$23.29 | \$23.56 | \$23.37 | \$23.38 |
| RT Delta % | 0.0% | 1.4% | -0.2% | 0.2% | 0.6% | 0.1% | -0.1% | 0.3% | 0.3% |

| July-20 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
|---------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Day-Ahead | \$23.93 | \$23.30 | \$23.72 | \$24.00 | \$23.65 | \$23.62 | \$23.88 | \$23.82 | \$23.78 |
| Real-Time | \$22.64 | \$22.23 | \$22.50 | \$22.70 | \$22.42 | \$22.35 | \$22.58 | \$22.52 | \$22.47 |
| RT Delta % | -5.4% | -4.6% | -5.1% | -5.4% | -5.2% | -5.4% | -5.4% | -5.5% | -5.5% |
| July-21 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Day-Ahead | \$37.95 | \$37.08 | \$37.21 | \$37.84 | \$37.41 | \$37.35 | \$37.79 | \$37.64 | \$37.59 |
| Real-Time | \$36.41 | \$35.78 | \$35.81 | \$36.27 | \$35.80 | \$35.84 | \$36.26 | \$36.08 | \$36.04 |
| RT Delta % | -4.1% | -3.5% | -3.8% | -4.1% | -4.3% | -4.0% | -4.0% | -4.1% | -4.1% |
| Annual Diff. | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Yr over Yr DA | 58.6% | 59.2% | 56.9% | 57.7% | 58.1% | 58.1% | 58.3% | 58.0% | 58.1% |
| Yr over Yr RT | 60.8% | 61.0% | 59.1% | 59.8% | 59.7% | 60.3% | 60.6% | 60.2% | 60.4% |


Monthly Average Fuel Price and RT Hub LMP Indexes



Underlying natural gas data furnished by:



Monthly Average Fuel Price and RT Hub LMP




Underlying natural gas data furnished by:




New England, NY, and PJM Hourly Average Real Time Prices by Month

Monthly, Last 13 Months



*Note: Hourly average prices are shown.

Daily: This Month




*Note: Hourly average prices are shown.




New England, NY, and PJM Average Peak Hour Real Time Prices

Monthly, Last 13 Months



Daily: This Month



*Forecasted New England daily peak hours reflected




Reserve Market Results – July 2021

- Maximum potential Forward Reserve Market payments of \$2.1M were reduced by credit reductions of \$29K, failure-to-reserve penalties of \$73K and failure-to-activate penalties of \$14K, resulting in a net payout of \$1.9M or 94% of maximum
 - Rest of System: \$1.55M/1.6M (97%)
 - Southwest Connecticut: \$0.04M/0.05M (81%)
 - Connecticut: \$0.33M/0.39M (87%)
- \$2.4M total Real-Time credits were reduced by \$788K in Forward Reserve Energy Obligation Charges for a net of \$1.6M in Real-Time Reserve payments
 - Rest of System: 215 hours, \$947K
 - Southwest Connecticut: 215 hours, \$314K
 - Connecticut: 215 hours, \$244K
 - NEMA: 215 hours, \$122K

Note: “Failure to reserve” results in both credit reductions and penalties in the Locational Forward Reserve Market. While this summary reports performance by location, there were no locational requirements in effect for the current Forward Reserve auction period.




LFRM Charges to Load by Load Zone (\$)




Zonal Increment Offers and Cleared Amounts


July Monthly Totals by Zone



Zonal Decrement Bids and Cleared Amounts




Total Increment Offers and Decrement Bids



Data excludes nodal offers and bids



Dispatchable vs. Non-Dispatchable Generation



* Dispatchable MWh here are defined to be all generation output that is not self-committed ('must run') by the customer.



REGIONAL SYSTEM PLAN (RSP)



Regional System Plan (RSP)

- RSP21 development continues
 - PAC and various regulatory bodies were sent a draft of the report on July 20 and comments are due by August 3
 - Stakeholder comments to be discussed at the August 18 PAC meeting
- RSP21 Public Meeting will be held virtually on October 6
 - Keynote speaker/panelists are being pursued
 - Panel Discussion: Grid of the Future: Preparing and Responding to Extreme Events

Planning Advisory Committee (PAC)

- August 18 PAC Meeting Agenda Topics*
 - Transmission Planning for the Clean-Energy Transition: Pilot Study Results and Proposed Changes to Assumptions
 - RSP21 Process Update
 - Singer 345 kV Substation - Flood Mitigation Project Update

* Agenda topics are subject to change. Visit <https://www.iso-ne.com/committees/planning/planning-advisory> for the latest PAC agendas.



Transmission Planning for the Clean Energy Transition

- On 9/24/20 the ISO initiated discussions with the PAC about proposed refinements to study assumptions that better reflect long-term trends, such as increased amounts of distributed-energy resources (primarily solar PV), offshore wind generation, and battery energy storage
- A follow-up presentation at the 11/19/20 PAC meeting outlined a proposal for a pilot study, with the following goals:
 - Explore transmission reliability concerns that may result from various system conditions possible by 2030
 - Quantify trade-offs necessary between transmission system reliability/flexibility and transmission investment cost
 - Inform future discussions on transmission planning study assumptions
- An overview of the system conditions and dispatch assumptions for the pilot study was discussed at the 12/16/20 and 1/21/21 PAC meetings
- Results were discussed at the 6/16/21 and 7/22/21 PAC meetings, with further discussion of results continuing throughout Q3



Economic Studies

- 2020 Economic Study Request
 - Study proponent is National Grid
 - Study simulations are complete, and results have been presented to PAC
 - Draft report to be completed by Q3 2021
- 2021 Economic Study Request
 - Also known as Future Grid Reliability Study – Phase 1 (FGRS)
 - Study proponent is NEPOOL
 - Preliminary production cost simulation results presented at the June and July PAC meetings; remaining preliminary production cost results expected at the September PAC meeting
 - Preliminary ancillary services analyses results to be presented at the September PAC meeting





Future Grid Reliability Study (FGRS)

- Phase 1
 - Studies include: Production Cost Simulations; Ancillary Services Simulations; Resource Adequacy Screen; and Probabilistic Resource Availability Analysis
 - Framework Document and supporting assumptions table, which describe study scenarios and objectives, have been developed by stakeholders
 - Phase 1 work was submitted as the only 2021 economic study
 - Production Cost Simulations preliminary results presented at the June and July PAC with remaining results to be presented in September
 - Ancillary Services Simulation initial results expected at the September PAC meeting
- Phase 2
 - Studies include: Revenue Sufficiency Analysis and Transmission Security
 - Studies will be delayed as the Pathways and 2050 Transmission studies are further defined
 - Studies likely to be performed by a consultant
 - Embellishment of the study scope continues at the MC/RC



Environmental Matters – Shift in Power System Emission Trends

- In the first half of 2021, power system carbon dioxide (CO₂) emissions increased, diverging from other system emission trends
 - Total system nitrogen oxide (-6%) and sulfur dioxide (-14%) emissions declined compared to the 2016-2020 average for the same period (January - June)
- Total CO₂ emissions increased by 7%, driven by greater natural-gas-fired generation, compared to the 2016-2020 average for the same period (January – June)
 - Total CO₂ emissions from all other emitting fuel categories declined in the first half of 2021




Environmental Matters – Massachusetts CO₂ Generator Emissions Cap

2021 CO₂ GWSA Emissions Trending Lower in July

- July 2021: YTD estimated CO₂ emissions range between 2.9 and 3.5 million metric tons (MMT)
 - 35% to 43% of the 8.23 MMT 2021 cap
- 6/9/21: GWSA auction clearing price was \$7.75 per metric ton
- Affected generators have access to banked allowances, in excess of expected 2021 emissions

2019-2021 Estimated Monthly Emissions (Thousand Metric Tons)



RSP Project Stage Descriptions

| Stage | Description |
|-------|--|
| 1 | Planning and Preparation of Project Configuration |
| 2 | Pre-construction (e.g., material ordering, project scheduling) |
| 3 | Construction in Progress |
| 4 | In Service |

Note: The listings in this section focus on major transmission line construction and rebuilding.



Greater Boston Projects

Status as of 7/23/2021

Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1213, 1220, 1365 | Install new 345 kV line from Scobie to Tewksbury | Dec-17 | 4 |
| 1527, 1528 | Reconductor the Y-151 115 kV line from Dracut Junction to Power Street | Apr-17 | 4 |
| 1212, 1549 | Reconductor the M-139 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury | May-17 | 4 |
| 1549 | Reconductor the N-140 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury | May-17 | 4 |
| 1260 | Reconductor the F-158N 115 kV line from Wakefield Junction to Maplewood and associated work at Maplewood | Dec-15 | 4 |
| 1550 | Reconductor the F-158S 115 kV line from Maplewood to Everett | Jun-19 | 4 |
| 1551, 1552 | Install new 345 kV cable from Woburn to Wakefield Junction, install two new 160 MVAR variable shunt reactors and associated work at Wakefield Junction and Woburn* | May-22 | 3* |
| 1329 | Refurbish X-24 69 kV line from Millbury to Northboro Road | Dec-15 | 4 |
| 1327 | Reconductor W-23W 69 kV line from Woodside to Northboro Road | Jun-19 | 4 |

* Substation portion of the project is a Present Stage status 4

Greater Boston Projects, cont.

Status as of 7/23/2021

Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|---|-----------------------------|---------------|
| 1330 | Separate X-24 and E-157W DCT | Dec-18 | 4 |
| 1363 | Separate Q-169 and F-158N DCT | Dec-15 | 4 |
| 1637, 1640 | Reconductor M-139/211-503 and N-140/211-504 115 kV lines from Pinehurst to North Woburn tap | May-17 | 4 |
| 1516 | Install new 115 kV station at Sharon to segment three 115 kV lines from West Walpole to Holbrook | Sep-20 | 4 |
| 965 | Install third 115 kV line from West Walpole to Holbrook | Sep-20 | 4 |
| 1558 | Install new 345 kV breaker in series with the 104 breaker at Stoughton | May-16 | 4 |
| 1199 | Install new 230/115 kV autotransformer at Sudbury and loop the 282-602 230 kV line in and out of the new 230 kV switchyard at Sudbury | Dec-17 | 4 |
| 1335 | Install a new 115 kV line from Sudbury to Hudson | Dec-23 | 2 |

Greater Boston Projects, cont.

Status as of 7/23/2021

Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability

| RSP Project List ID | Upgrade | Expected/Actual In-Service | Present Stage |
|---------------------|--|----------------------------|---------------|
| 1336 | Replace 345/115 kV autotransformer, 345 kV breakers, and 115 kV switchgear at Woburn | Dec-19 | 4 |
| 1553 | Install a 345 kV breaker in series with breaker 104 at Woburn | Jun-17 | 4 |
| 1337 | Reconfigure Waltham by relocating PARs, 282-507 line, and a breaker | Dec-17 | 4 |
| 1339 | Upgrade 533-508 115 kV line from Lexington to Hartwell and associated work at the stations | Aug-16 | 4 |
| 1521 | Install a new 115 kV 54 MVAR capacitor bank at Newton | Dec-16 | 4 |
| 1522 | Install a new 115 kV 36.7 MVAR capacitor bank at Sudbury | May-17 | 4 |
| 1352 | Install a second Mystic 345/115 kV autotransformer and reconfigure the bus | May-19 | 4 |
| 1353 | Install a 115 kV breaker on the East bus at K Street | Jun-16 | 4 |
| 1354, 1738 | Install 115 kV cable from Mystic to Chelsea and upgrade Chelsea 115 kV station to BPS standards | Jul-21 | 3* |
| 1355 | Split 110-522 and 240-510 DCT from Baker Street to Needham for a portion of the way and install a 115 kV cable for the rest of the way | Mar-21 | 4 |

*Mystic to Chelsea line portion of the project is a present stage 4 as of October 2020.

Greater Boston Projects, cont.

Status as of 7/23/2021

Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1356 | Install a second 115 kV cable from Mystic to Woburn to create a bifurcated 211-514 line | May-22 | 3 |
| 1357 | Open lines 329-510/511 and 250-516/517 at Mystic and Chatham, respectively. Operate K Street as a normally closed station. | May-19 | 4 |
| 1518 | Upgrade Kingston to create a second normally closed 115 kV bus tie and reconfigure the 345 kV switchyard | Mar-19 | 4 |
| 1519 | Relocate the Chelsea capacitor bank to the 128-518 termination postion | Dec-16 | 4 |



Greater Boston Projects, cont.

Status as of 7/23/2021

Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|---|-----------------------------------|---------------|
| 1520 | Upgrade North Cambridge to mitigate 115 kV 5 and 10 stuck breaker contingencies | Dec-17 | 4 |
| 1643 | Install a 200 MVAR STATCOM at Coopers Mills | Nov-18 | 4 |
| 1341, 1645 | Install a 115 kV 36.7 MVAR capacitor bank at Hartwell | May-17 | 4 |
| 1646 | Install a 345 kV 160 MVAR shunt reactor at K Street | Dec-19 | 4 |
| 1647 | Install a 115 kV breaker in series with the 5 breaker at Framingham | Mar-17 | 4 |
| 1554 | Install a 115 kV breaker in series with the 29 breaker at K Street | Apr-17 | 4 |



SEMA/RI Reliability Projects

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area

| RSP Project List ID | Upgrade | Expected/Actual In-Service | Present Stage |
|---------------------|--|----------------------------|---------------|
| 1714 | Construct a new 115 kV GIS switching station (Grand Army) which includes remote terminal station work at Brayton Point and Somerset substations, and the looping in of the E-183E, F-184, X3, and W4 lines | Oct-20 | 4 |
| 1742 | Conduct remote terminal station work at the Wampanoag and Pawtucket substations for the new Grand Army GIS switching station | Oct-20 | 4 |
| 1715 | Install upgrades at Brayton Point substation which include a new 115 kV breaker, new 345/115 kV transformer, and upgrades to E183E, F184 station equipment | Oct-20 | 4 |
| 1716 | Increase clearances on E-183E & F-184 lines between Brayton Point and Grand Army substations | Nov-19 | 4 |
| 1717 | Separate the X3/W4 DCT and reconductor the X3 and W4 lines between Somerset and Grand Army substations; reconfigure Y2 and Z1 lines | Nov-19 | 4 |

SEMA/RI Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1718 | Add 115 kV circuit breaker at Robinson Ave substation and re-terminate the Q10 line | Dec-21 | 3 |
| 1719 | Install 45.0 MVAR capacitor bank at Berry Street substation | Cancelled* | N/A |
| 1720 | Separate the N12/M13 DCT and reconductor the N12 and M13 between Somerset and Bell Rock substations | May-25 | 2 |
| 1721 | Reconfigure Bell Rock to breaker-and-a-half station, split the M13 line at Bell Rock substation, and terminate 114 line at Bell Rock; install a new breaker in series with N12/D21 tie breaker, upgrade D21 line switch, and install a 37.5 MVAR capacitor | Dec-23 | 2 |
| 1722 | Extend the Line 114 from the Dartmouth town line (Eversource- NGRID border) to Bell Rock substation | Dec-23 | 2 |
| 1723 | Reconductor L14 and M13 lines from Bell Rock substation to Bates Tap | Cancelled* | N/A |

*Cancelled per ISO-NE PAC presentation on August 27, 2020

SEMA/RI Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1725 | Build a new 115 kV line from Bourne to West Barnstable substations which includes associated terminal work | Dec-23 | 1 |
| 1726 | Separate the 135/122 DCT from West Barnstable to Barnstable substations | Dec-21 | 3 |
| 1727 | Retire the Barnstable SPS | Dec-21 | 3 |
| 1728 | Build a new 115 kV line from Carver to Kingston substations and add a new Carver terminal | Dec-22 | 1 |
| 1729 | Install a new bay position at Kingston substation to accommodate new 115 kV line | Dec-22 | 1 |
| 1730 | Extend the 114 line from the Eversource/National Grid border to the Industrial Park Tap | Dec-23 | 1 |



SEMA/RI Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area

| RSP Project List ID | Upgrade | Expected/Actual In-Service | Present Stage |
|---------------------|---|----------------------------|---------------|
| 1731 | Install 35.3 MVAR capacitors at High Hill and Wing Lane substations | Dec-21 | 3 |
| 1732 | Loop the 201-502 line into the Medway substation to form the 201-502N and 201-502S lines | Jan-23 | 3 |
| 1733 | Separate the 325/344 DCT lines from West Medway to West Walpole substations | Cancelled** | N/A |
| 1734 | Reconductor and upgrade the 112 Line from the Tremont substation to the Industrial Tap | Jun-18 | 4 |
| 1736 | Reconductor the 108 line from Bourne substation to Horse Pond Tap* | Oct-18 | 4 |
| 1737 | Replace disconnect switches on 323 line at West Medway substation and replace 8 line structures | Aug-20 | 4 |

* Does not include the reconductoring work over the Cape Cod canal

** Cancelled per ISO-NE PAC presentation on August 27, 2020



SEMA/RI Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area

| RSP Project List ID | Upgrade | Expected/Actual In-Service | Present Stage |
|---------------------|---|----------------------------|---------------|
| 1741 | Rebuild the Middleborough Gas and Electric portion of the E1 line from Bridgewater to Middleborough | Apr-19 | 4 |
| 1782 | Reconductor the J16S line | Jun-22 | 2 |
| 1724 | Replace the Kent County 345/115 kV transformer | Mar-22 | 2 |
| 1789 | West Medway 345 kV circuit breaker upgrades | Apr-21 | 4 |
| 1790 | Medway 115 kV circuit breaker replacements | Nov-20 | 4 |



Eastern CT Reliability Projects

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Eastern Connecticut area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1815 | Reconductor the L190-4 and L190-5 line sections | Dec-26 | 1 |
| 1850 | Install a second 345/115 kV autotransformer (4X) and one 345 kV breaker at Card substation | Mar-23 | 2 |
| 1851 | Upgrade Card 115 kV to BPS standards | Mar-23 | 2 |
| 1852 | Install one 115 kV circuit breaker in series with Card substation 4T | Mar-23 | 2 |
| 1853 | Convert Gales Ferry substation from 69 kV to 115 kV | Dec-23 | 1 |
| 1854 | Rebuild the 100 Line from Montville to Gales Ferry to allow operation at 115 kV | Dec-22 | 1 |



Eastern CT Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Eastern Connecticut area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------|---------------|
| 1855 | Re-terminate the 100 Line at Montville station and associated work. Energize the 100 Line at 115 kV | Dec-23 | 1 |
| 1856 | Rebuild 400-1 Line section to allow operation at 115 kV (Tunnel to Ledyard Jct.) | Dec-22 | 1 |
| 1857 | Add one 115 kV circuit breaker and re-terminate the 400-1 line section into Tunnel substation. Energize 400 Line at 115 kV | Dec-23 | 1 |
| 1858 | Rebuild 400-2 Line section to allow operation at 115 kV (Ledyard Jct. to Border Bus with CMEEC) | Dec-21 | 3 |
| 1859 | Rebuild the 400-3 Line Section to allow operation at 115 kV (Gales Ferry to Ledyard Jct.) | Dec-22 | 1 |
| 1860 | Install a 25.2 MVAR 115 kV capacitor and one capacitor breaker at Killingly | Mar-22 | 2 |

Eastern CT Reliability Projects, cont.

Status as of 7/23/2021

Project Benefit: Addresses system needs in the Eastern Connecticut area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|---|-----------------------------|---------------|
| 1861 | Install one 345 kV series breaker with the Montville 1T | June-22 | 2 |
| 1862 | Install a 50 MVAR synchronous condenser with two 115 kV breakers at Shunock | Dec-24 | 1 |
| 1863 | Install a 1% series reactor with bypass switch at Mystic, CT on the 1465 Line | Dec-22 | 1 |
| 1864 | Convert the 400-2 Line Section to 115 kV (Border Bus to Buddington), convert Buddington to 115 kV | Dec-23 | 1 |



Boston Area Optimized Solution Projects


Status as of 7/23/2021

Project Benefit: Addresses system needs in the Boston area

| RSP Project List ID | Upgrade | Expected/ Actual In-Service | Present Stage |
|---------------------|--|-----------------------------------|---------------|
| 1874 | Install two 11.9 ohm series reactors at North Cambridge Station on Lines 346 and 365 | Jun-23 | 3 |
| 1875 | Install a direct transfer trip (DTT) scheme between Ward Hill and West Amesbury Substations for Line 394 | Jan-23 | 1 |
| 1876 | Install one +/- 167 MVAR STATCOM at Tewksbury 345 kV Substation | Oct-23 | 1 |



Status of Tariff Studies



Generator Project Status


Note: July 2021 is based on partial data.

As of July 2021, there is 2 ETU in Scoping, 0 in FS, 3 in SIS, 0 in OIS, 1 in FAC, 0 Negotiating IA, and 2 with Executed IA.

<https://irtt.iso-ne.com/external.aspx>

What is in the Queue (as of July 27, 2021)

Storage Projects are proposed as stand-alone storage or as co-located with wind or solar projects



OPERABLE CAPACITY ANALYSIS

Summer 2021 and Preliminary Fall 2021



OPERABLE CAPACITY ANALYSIS

Summer 2021 Analysis



Summer 2021 Operable Capacity Analysis

| 50/50 Load Forecast (Reference) | September - 2021 ² CSO (MW) | September - 2021 ² SCC (MW) |
|---|---|---|
| Operable Capacity MW ¹ | 29,368 | 29,927 |
| Active Demand Capacity Resource (+) ⁵ | 540 | 459 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,208 | 1,208 |
| Non Commercial Capacity (+) | 45 | 45 |
| Non Gas-fired Planned Outage MW (-) | 2,063 | 2,670 |
| Gas Generator Outages MW (-) | 368 | 406 |
| Allowance for Unplanned Outages (-) ⁴ | 2,100 | 2,100 |
| Generation at Risk Due to Gas Supply (-) ³ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) | 26,630 | 26,463 |
| Peak Load Forecast MW(adjusted for Other Demand Resources) ² | 24,810 | 24,810 |
| Operating Reserve Requirement MW | 2,305 | 2,305 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 27,115 | 27,115 |
| Operable Capacity Margin | -484 | -652 |

¹ Operable Capacity is based on data as of **July 27, 2021** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **July 27, 2021**.

² Load forecast that is based on the 2021 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 11, 2021**.

³ Total of (Gas at Risk MW) – (Gas Gen Outages MW).

⁴ Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

⁵ Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

Summer 2021 Operable Capacity Analysis

| 90/10 Load Forecast | September - 2021 ² CSO (MW) | September - 2021 ² SCC (MW) |
|---|---|---|
| Operable Capacity MW ¹ | 29,368 | 29,927 |
| Active Demand Capacity Resource (+) ⁵ | 540 | 459 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,208 | 1,208 |
| Non Commercial Capacity (+) | 45 | 45 |
| Non Gas-fired Planned Outage MW (-) | 2,063 | 2,670 |
| Gas Generator Outages MW (-) | 368 | 406 |
| Allowance for Unplanned Outages (-) ⁴ | 2,100 | 2,100 |
| Generation at Risk Due to Gas Supply (-) ³ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) | 26,630 | 26,463 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 26,711 | 26,711 |
| Operating Reserve Requirement MW | 2,305 | 2,305 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 29,016 | 29,016 |
| Operable Capacity Margin | -2,385 | -2,553 |

¹ Operable Capacity is based on data as of **July 27, 2021** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **July 27, 2021**.

² Load forecast that is based on the 2021 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 11, 2021**.

³ Total of (Gas at Risk MW) – (Gas Gen Outages MW).

⁴ Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

⁵ Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

Summer 2021 Operable Capacity Analysis

50/50 Forecast (Reference)

ISO-NE OPERABLE CAPACITY ANALYSIS

July 27, 2021 - 50-50 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, August, and Mid September.

Report created: 7/27/2021

| Study Week (Week Beginning, Saturday) | CSO Supply Resource Capacity MW | CSO Demand Resource Capacity MW | External Node Capacity MW | Non- Commercial Capacity MW | CSO Non Gas- Only Generator Planned Outages MW | CSO Gas-Only Generator Planned Outages MW | Unplanned Outages Allowance MW | CSO Generation at Risk Due to Gas Supply 50- 50PLE MW | CSO Net Available Capacity MW | Peak Load Forecast 50- 50PLE MW | Operating Reserve Requirement MW | CSO Net Required Capacity MW | CSO Operable Capacity Margin MW | Season Min OpCap Margin Flag | Season_Label |
|--|---------------------------------------|---------------------------------------|------------------------------|-----------------------------------|--|--|---|---|-------------------------------------|---------------------------------------|---|------------------------------------|---------------------------------------|------------------------------------|--------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| 8/14/2021 | 29150 | 502 | 1160 | 44 | 75 | 176 | 2100 | 0 | 28507 | 24810 | 2305 | 27115 | 1392 | N | Summer 2021 |
| 8/21/2021 | 29150 | 502 | 1103 | 44 | 38 | 0 | 2100 | 0 | 28662 | 24810 | 2305 | 27115 | 1547 | N | Summer 2021 |
| 8/28/2021 | 29150 | 502 | 1160 | 44 | 32 | 0 | 2100 | 0 | 28725 | 24810 | 2305 | 27115 | 1610 | N | Summer 2021 |
| 9/4/2021 | 29368 | 540 | 1208 | 45 | 1334 | 0 | 2100 | 0 | 27728 | 24810 | 2305 | 27115 | 613 | N | Summer 2021 |
| 9/11/2021 | 29368 | 540 | 1208 | 45 | 2063 | 368 | 2100 | 0 | 26630 | 24810 | 2305 | 27115 | -484 | Y | Summer 2021 |

Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply Mw:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2021 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

Summer 2021 Operable Capacity Analysis

90/10 Forecast

ISO-NE OPERABLE CAPACITY ANALYSIS

July 27, 2021 - 90/10 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, August, and Mid September.

Report created: 7/27/2021

| Study Week (Week Beginning , Saturday) | CSO Supply Resource Capacity MW | CSO Demand Resource Capacity MW | External Node Capacity MW | Non- Commercial Capacity MW | CSO Non Gas-Only Generator Planned Outages MW | CSO Gas- Only Generator Planned Outages MW | Unplanned Outages Allowance MW | CSO Generation at Risk Due to Gas Supply 90- 10PLE MW | CSO Net Available Capacity MW | Peak Load Forecast 90- 10PLE MW | Operating Reserve Requireme nt MW | CSO Net Required Capacity MW | CSO Operable Capacity Margin MW | Season Min Opcap Margin Flag | Season_Label |
|---|--|---|------------------------------------|--------------------------------------|--|---|---|--|--|---------------------------------------|--|---------------------------------------|--|------------------------------------|--------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| 8/14/2021 | 29150 | 502 | 1160 | 44 | 75 | 176 | 2100 | 0 | 28507 | 26711 | 2305 | 29016 | -509 | N | Summer 2021 |
| 8/21/2021 | 29150 | 502 | 1103 | 44 | 38 | 0 | 2100 | 0 | 28662 | 26711 | 2305 | 29016 | -354 | N | Summer 2021 |
| 8/28/2021 | 29150 | 502 | 1160 | 44 | 32 | 0 | 2100 | 0 | 28725 | 26711 | 2305 | 29016 | -291 | N | Summer 2021 |
| 9/4/2021 | 29368 | 540 | 1208 | 45 | 1334 | 0 | 2100 | 0 | 27728 | 26711 | 2305 | 29016 | -1288 | N | Summer 2021 |
| 9/11/2021 | 29368 | 540 | 1208 | 45 | 2063 | 368 | 2100 | 0 | 26630 | 26711 | 2305 | 29016 | -2385 | Y | Summer 2021 |


Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply Mw:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8-9)
- Peak Load Forecast MW:** Provided in the annual 2021 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

*Highlighted week is based on the week determined by the 50/50 Load Forecast Reference week


Summer 2021 Operable Capacity Analysis

50/50 Forecast (Reference)



Summer 2021 Operable Capacity Analysis

90/10 Forecast



OPERABLE CAPACITY ANALYSIS

Preliminary Fall 2021 Analysis



Preliminary Fall 2021 Operable Capacity Analysis

| 50/50 Load Forecast (Reference) | September - 2021 ² CSO (MW) | September - 2021 ² SCC (MW) |
|---|---|---|
| Operable Capacity MW ¹ | 29,368 | 29,927 |
| Active Demand Capacity Resource (+) ⁵ | 540 | 459 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 766 | 766 |
| Non Commercial Capacity (+) | 45 | 45 |
| Non Gas-fired Planned Outage MW (-) | 3,550 | 4,173 |
| Gas Generator Outages MW (-) | 1,992 | 2,045 |
| Allowance for Unplanned Outages (-) ⁴ | 2,100 | 2,100 |
| Generation at Risk Due to Gas Supply (-) ³ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) | 23,077 | 22,879 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 20,658 | 20,658 |
| Operating Reserve Requirement MW | 2,305 | 2,305 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 22,963 | 22,963 |
| Operable Capacity Margin | 115 | -83 |

¹ Operable Capacity is based on data as of **July 27, 2021** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **July 27, 2021**.

² Load forecast that is based on the 2021 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 25, 2021**.

³ Total of (Gas at Risk MW) – (Gas Gen Outages MW).

⁴ Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

⁵ Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

Preliminary Fall 2021 Operable Capacity Analysis

| 90/10 Load Forecast | September - 2021 ² CSO (MW) | September - 2021 ² SCC (MW) |
|---|---|---|
| Operable Capacity MW ¹ | 29,368 | 29,927 |
| Active Demand Capacity Resource (+) ⁵ | 540 | 459 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 766 | 766 |
| Non Commercial Capacity (+) | 45 | 45 |
| Non Gas-fired Planned Outage MW (-) | 3,550 | 4,173 |
| Gas Generator Outages MW (-) | 1,992 | 2,045 |
| Allowance for Unplanned Outages (-) ⁴ | 2,100 | 2,100 |
| Generation at Risk Due to Gas Supply (-) ³ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) | 23,077 | 22,879 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 22,280 | 22,280 |
| Operating Reserve Requirement MW | 2,305 | 2,305 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 24,585 | 24,585 |
| Operable Capacity Margin | -1,507 | -1,705 |

¹ Operable Capacity is based on data as of **July 27, 2021** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **July 27, 2021**.

² Load forecast that is based on the 2021 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 25, 2021**.

³ Total of (Gas at Risk MW) – (Gas Gen Outages MW).

⁴ Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

⁵ Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.



Preliminary Fall 2021 Operable Capacity Analysis

50/50 Forecast (Reference)

ISO-NE OPERABLE CAPACITY ANALYSIS

July 27, 2021 - 50-50 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, August, and Mid September.

Report created: 7/27/2021

| Study Week (Week Beginning, Saturday) | CSO Supply Resource Capacity MW | CSO Demand Resource Capacity MW | External Node Capacity MW | Non-Commercial Capacity MW | CSO Non Gas-Only Generator Planned Outages MW | CSO Gas-Only Generator Planned Outages MW | Unplanned Outages Allowance MW | CSO Generation at Risk Due to Gas Supply 50-50PLE MW | CSO Net Available Capacity MW | Peak Load Forecast 50-50PLE MW | Operating Reserve Requirement MW | CSO Net Required Capacity MW | CSO Operable Capacity Margin MW | Season Min Opcap Margin Flag | Season_Label |
|--|---------------------------------|---------------------------------|---------------------------|----------------------------|---|---|--------------------------------|--|-------------------------------|--------------------------------|----------------------------------|------------------------------|---------------------------------|------------------------------|--------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| 9/18/2021 | 29368 | 540 | 766 | 45 | 3118 | 1012 | 2100 | 0 | 24489 | 20751 | 2305 | 23056 | 1434 | N | Fall 2021 |
| 9/25/2021 | 29368 | 540 | 766 | 45 | 3550 | 1992 | 2100 | 0 | 23077 | 20658 | 2305 | 22963 | 115 | Y | Fall 2021 |
| 10/2/2021 | 29751 | 540 | 1135 | 50 | 4855 | 3312 | 2800 | 0 | 20509 | 14789 | 2305 | 17094 | 3416 | N | Fall 2021 |
| 10/9/2021 | 29751 | 540 | 1135 | 50 | 4419 | 3141 | 2800 | 0 | 21116 | 14825 | 2305 | 17130 | 3987 | N | Fall 2021 |
| 10/16/2021 | 29751 | 540 | 1135 | 50 | 5110 | 3416 | 2800 | 0 | 20149 | 15749 | 2305 | 18054 | 2096 | N | Fall 2021 |
| 10/23/2021 | 29751 | 540 | 1078 | 50 | 5345 | 2422 | 2800 | 0 | 20852 | 16113 | 2305 | 18418 | 2434 | N | Fall 2021 |
| 10/30/2021 | 29751 | 540 | 1135 | 50 | 4226 | 1101 | 3600 | 0 | 22548 | 16320 | 2305 | 18625 | 3924 | N | Fall 2021 |
| 11/6/2021 | 29751 | 540 | 1135 | 50 | 2179 | 1187 | 3600 | 0 | 24509 | 16435 | 2305 | 18740 | 5770 | N | Fall 2021 |
| 11/13/2021 | 29751 | 540 | 1135 | 50 | 1185 | 767 | 3600 | 49 | 25875 | 16780 | 2305 | 19085 | 6790 | N | Fall 2021 |
| 11/20/2021 | 29751 | 540 | 1135 | 50 | 1057 | 610 | 3600 | 816 | 25393 | 17517 | 2305 | 19822 | 5571 | N | Fall 2021 |

Column Definitions

1. **CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
2. **CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
3. **External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
4. **Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
5. **CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
6. **CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
7. **Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
8. **CSO Generation at Risk Due to Gas Supply MW:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
9. **CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
10. **Peak Load Forecast MW:** Provided in the annual 2021 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
11. **Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
12. **CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
13. **CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
14. **Operable Capacity Season Label:** Applicable season and year.
15. **Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

Preliminary Fall 2021 Operable Capacity Analysis

90/10 Forecast

ISO-NE OPERABLE CAPACITY ANALYSIS

July 27, 2021 - 90/10 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, August, and Mid September.

Report created: 7/27/2021

| Study Week (Week Beginning , Saturday) | CSO Supply Resource Capacity MW | CSO Demand Resource Capacity MW | External Node Capacity MW | Non- Commercial Capacity MW | CSO Non Gas-Only Generator Planned Outages MW | CSO Gas- Only Generator Planned Outages MW | Unplanned Outages Allowance MW | CSO Generation at Risk Due to Gas Supply 90- 10PLE MW | CSO Net Available Capacity MW | Peak Load Forecast 90- 10PLE MW | Operating Reserve Requireme nt MW | CSO Net Required Capacity MW | CSO Operable Capacity Margin MW | Season Min Opcap Margin Flag | Season_Label |
|---|--|---|------------------------------------|--------------------------------------|--|---|---|--|--|---------------------------------------|--|---------------------------------------|--|------------------------------------|--------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| 9/18/2021 | 29368 | 540 | 766 | 45 | 3118 | 1012 | 2100 | 0 | 24489 | 22380 | 2305 | 24685 | -195 | N | Fall 2021 |
| 9/25/2021 | 29368 | 540 | 766 | 45 | 3550 | 1992 | 2100 | 0 | 23077 | 22280 | 2305 | 24585 | -1507 | Y | Fall 2021 |
| 10/2/2021 | 29751 | 540 | 1135 | 50 | 4855 | 3312 | 2800 | 0 | 20509 | 15292 | 2305 | 17597 | 2913 | N | Fall 2021 |
| 10/9/2021 | 29751 | 540 | 1135 | 50 | 4419 | 3141 | 2800 | 0 | 21116 | 15328 | 2305 | 17633 | 3484 | N | Fall 2021 |
| 10/16/2021 | 29751 | 540 | 1135 | 50 | 5110 | 3416 | 2800 | 0 | 20149 | 16279 | 2305 | 18584 | 1566 | N | Fall 2021 |
| 10/23/2021 | 29751 | 540 | 1078 | 50 | 5345 | 2422 | 2800 | 0 | 20852 | 16654 | 2305 | 18959 | 1893 | N | Fall 2021 |
| 10/30/2021 | 29751 | 540 | 1135 | 50 | 4226 | 1101 | 3600 | 0 | 22548 | 16866 | 2305 | 19171 | 3378 | N | Fall 2021 |
| 11/6/2021 | 29751 | 540 | 1135 | 50 | 2179 | 1187 | 3600 | 0 | 24509 | 16985 | 2305 | 19290 | 5220 | N | Fall 2021 |
| 11/13/2021 | 29751 | 540 | 1135 | 50 | 1185 | 767 | 3600 | 415 | 25509 | 17339 | 2305 | 19644 | 5865 | N | Fall 2021 |
| 11/20/2021 | 29751 | 540 | 1135 | 50 | 1057 | 610 | 3600 | 987 | 25222 | 18098 | 2305 | 20403 | 4819 | N | Fall 2021 |


Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply MW:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2021 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

*Highlighted week is based on the week determined by the 50/50 Load Forecast Reference week


Preliminary Fall 2021 Operable Capacity Analysis

50/50 Forecast (Reference)



Preliminary Fall 2021 Operable Capacity Analysis

90/10 Forecast



OPERABLE CAPACITY ANALYSIS

Appendix



Possible Relief Under OP4: Appendix A

| OP 4 Action Number | Page 1 of 2 Action Description | Amount Assumed Obtainable Under OP 4 (MW) |
|--------------------|---|---|
| 1 | Implement Power Caution and advise Resources with a CSO to prepare to provide capacity and notify “Settlement Only” generators with a CSO to monitor reserve pricing to meet those obligations. Begin to allow the depletion of 30-minute reserve. | 0 ¹ 600 |
| 2 | Declare Energy Emergency Alert (EEA) Level 1 ⁴ | 0 |
| 3 | Voluntary Load Curtailment of Market Participants’ facilities. | 40 ² |
| 4 | Implement Power Watch | 0 |
| 5 | Schedule Emergency Energy Transactions and arrange to purchase Control Area-to-Control Area Emergency | 1,000 |
| 6 | Voltage Reduction requiring > 10 minutes | 125 ³ |

NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test.
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations



Possible Relief Under OP4: Appendix A

| OP 4 Action Number | Page 2 of 2 Action Description | Amount Assumed Obtainable Under OP 4 (MW) |
|--------------------|---|---|
| 7 | Request generating resources not subject to a Capacity Supply Obligation to voluntarily provide energy for reliability purposes | 0 |
| 8 | 5% Voltage Reduction requiring 10 minutes or less | 250 ³ |
| 9 | Transmission Customer Generation Not Contractually Available to Market Participants during a Capacity Deficiency. Voluntary Load Curtailment by Large Industrial and Commercial Customers. | 5 200 ² |
| 10 | Radio and TV Appeals for Voluntary Load Curtailment Implement Power Warning | 200 ² |
| 11 | Request State Governors to Reinforce Power Warning Appeals. | 100 ² |
| Total | | 2,520 |

NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations

