



# NEPOOL Participants Committee Report

---

*July 2022*

Vamsi Chadalavada

EXECUTIVE VICE PRESIDENT AND CHIEF OPERATING OFFICER



# Table of Contents

• Highlights	Page	3
• System Operations	Page	11
• Market Operations	Page	24
• Back-Up Detail	Page	41
– Demand Response	Page	42
– New Generation	Page	44
– Forward Capacity Market	Page	51
– Reliability Costs - Net Commitment Period Compensation (NCPC) Operating Costs	Page	57
– Regional System Plan (RSP)	Page	86
– Operable Capacity Analysis –Summer 2022 Analysis	Page	114
– Operable Capacity Analysis – Appendix	Page	121





# Regular Operations Report - Highlights

---



# Highlights

- Day-Ahead (DA), Real-Time (RT) Prices and Transactions
  - Update: May 2022 Energy Market value totaled \$777M
  - June 2022 Energy market value was \$741M, down \$36M from May 2022 and up \$262M from June 2021
    - June 2022 natural gas prices over the period were 7.2% lower than May average values
    - Average RT Hub Locational Marginal Prices (\$71.71/MWh) over the period were 4.1% lower than May averages
      - Average DA Hub: \$68.43/MWh
    - Average June 2022 natural gas prices and RT Hub LMPs over the period were up 156% and 100%, respectively, from June 2021 averages
  - Average DA cleared physical energy during the peak hours as percent of forecasted load was 97% during June, down from 98.3% during May\*
    - The minimum value for the month was 92.6% on Wednesday, Sunday, June 12<sup>th</sup>\*\*

\*DA Cleared Physical Energy is the sum of Generation and Net Imports cleared in the DA Energy Market

Underlying natural gas data furnished by:



# Highlights, cont.


- Daily Net Commitment Period Compensation (NCPC)
  - June 2022 NCPC payments totaled \$3M over the period, down \$2.4M from May 2022 and down \$0.9M from June 2021
    - First Contingency payments totaled \$3M, down \$2.4M from May
      - \$2.5M paid to internal resources, down \$1.8M from May
        - » \$450K charged to DALO, \$1.3M to RT Deviations, \$723K to RTLO\*
      - \$465K paid to resources at external locations, down \$541K from May
        - » \$449K charged to DALO at external locations, \$16K to RT Deviations
    - Second Contingency payments totaled \$27K, up \$27K from May
    - Voltage and Distribution payments were both zero
  - NCPC payments over the period as percent of Energy Market value were 0.4%

**\* NCPC types reflected in the First Contingency Amount: Dispatch Lost Opportunity Cost (DLOC) - \$350K; Rapid Response Pricing (RRP) Opportunity Cost - \$373K; Posturing - \$0K; Generator Performance Auditing (GPA) - \$0K**




# Price Responsive Demand (PRD) Energy Market Activity by Month

## DA, RT, and RT Dev MWh



## Market Value



Note: DA and RT (deviation) MWh are settlement obligations and reflect appropriate gross-ups for distribution losses.



# Highlights

- 2021 Economic Study (FGRS Phase 1) gaps, key takeaways, and lessons learned were presented at the June 15 PAC meeting and the draft report has been posted
- At the June 29 Power Supply Planning Committee (PSPC) meeting, ISO confirmed the zones to be modeled for FCA 17
  - Export-constrained zones: Northern New England and Maine nested inside Northern New England
  - Import-constrained zones: None



# Forward Capacity Market (FCM) Highlights

- CCP 13 (2022-2023)
  - Third and final annual reconfiguration auction (ARA3) was held on March 1-3, and results were posted on March 30
- CCP 14 (2023-2024)
  - Second annual reconfiguration auction (ARA2) will be held on August 1-3, and results will be posted no later than August 31
- CCP 15 (2024-2025)
  - First annual reconfiguration auction (ARA1) was held on June 1-3, and results will be posted no later than July 5
- CCP 16 (2025-2026)
  - Auction results were filed with FERC on March 21 and the filing is pending
    - ISO requested an effective date of July 19; comments were due May 5; ISO answered comments on May 16



# FCM Highlights, cont.

- CCP 17 (2026-2027)
  - Capacity zone development discussions began at the November 17, 2021 PAC meeting, with follow-up discussion at the April 27 RC and April 28 PAC meetings
    - All subsequent reconfiguration auctions model the same zones as the FCA
  - ISO posted existing capacity values on April 29
  - ISO posted the Retirement and Permanent De-List Bid summary on May 11
  - Show of Interest Submission Window closed on June 6
  - ISO submitted the “MOPR Removal” filing to FERC on March 31, which includes a “Transition Mechanism” for FCA 17 and FCA 18
    - FERC issued an order accepting ISO’s filing on May 27



# Highlights

- The next Load Forecast Committee meeting is rescheduled for September 23 and will kick off the 2023 forecast cycle
- The lowest 50/50 and 90/10 Summer Operable Capacity Margins are projected for week beginning September 10, 2022.



# SYSTEM OPERATIONS



# System Operations

<b><u>Weather Patterns</u></b>	Boston	Temperature: Below Normal (-0.1°F) Max: 90°F, Min: 51°F Precipitation: 2.33" – Below Normal Normal: 3.89"	Hartford	Temperature: Below Normal (-0.1°F) Max: 92°F, Min: 48°F Precipitation: 2.59" - Below Normal Normal: 4.28"
--------------------------------	--------	--------------------------------------------------------------------------------------------------------------------	----------	--------------------------------------------------------------------------------------------------------------------

<b><u>Peak Load:</u></b>	19,664 MW	Jun 26, 2022	19:00 (ending)
--------------------------	-----------	--------------	----------------

## Emergency Procedure Events (OP-4, M/LCC 2, Minimum Generation Emergency)

Procedure	Declared	Cancelled	Note
None for June 2022			



# System Operations


## NPCC Simultaneous Activation of Reserve Events

Date	Area	MW Lost
6/22	IESO	945



# 2022 System Operations - Load Forecast Accuracy

Dashboard  
Indicator




Month	J	F	M	A	M	J	J	A	S	O	N	D	
Day Max	3.97	3.07	4.92	5.66	6.52	3.71							6.52
Day Min	0.69	0.87	0.97	0.85	0.91	0.79							0.69
MAPE	1.79	1.81	1.93	2.05	2.30	1.90							1.97
Goal	1.80	1.80	1.80	1.80	2.00	2.60							

# 2022 System Operations - Load Forecast Accuracy cont.

Dashboard  
Indicator



Peak Hours  
Monthly Average, Daily Maximum and Minimum,  
Based on forecast published at 1000 on day before Operating Day




Month	J	F	M	A	M	J	J	A	S	O	N	D	
Day Max	6.01	2.85	3.32	6.08	9.27	6.70							9.27
Day Min	0.02	0.03	0.04	0.00	0.06	0.01							0.00
MAPE	1.25	1.11	1.13	1.29	2.14	2.33							1.55
Goal	1.80	1.80	1.80	1.80	2.00	2.60							

# 2022 System Operations - Load Forecast Accuracy cont.

Percent of Hours Actual Load  
Above vs. Below Forecast  
Based on LF published by 1000, day before Operating Day


Target = 50%  
Plus/Minus = 5%



	J	F	M	A	M	J	J	A	S	O	N	D	Avg
Above %	55.2	46	39.7	45.6	57.8	57.1							50
Below %	44.8	54	60.3	54.4	42.2	42.9							50
Avg Above	219.5	245.7	175.9	180	217.2	208.6							246
Avg Below	-223.1	-207.6	-240.0	-191.5	-192.2	-208.9							-240
Avg All	22	6	-78	-18	30	27							-2




# 2022 System Operations - Load Forecast Accuracy cont.




# Monthly Recorded Net Energy for Load (NEL) and Weather Normalized NEL

Net Energy for Load (NEL)



Ann Tot (TWh): 119.2 116.9 118.8 57.3


Weather Normalized NEL




Ann Tot (TWh): 118.8 116.3 117.6 47.4

NEPOOL NEL is the total net revenue quality metered energy required to serve load and is analogous to 'RT system load.' NEL is calculated as: Generation – pumping load + net interchange where imports are positively signed. Current month's data may be preliminary. Weather normalized NEL is typically reported on a one-month lag.

# Monthly Peak Loads and Weather Normalized Seasonal Peak History



\*Revenue quality metered value




Winter beginning in year displayed

F – designates forecasted values, which are typically updated in April/May of the following year; represents “net forecast” (i.e., the gross forecast net of passive demand response and behind-the-meter solar demand)




# Wind Power Forecast Error Statistics: Medium and Long Term Forecasts MAE



Ideally, MAE and Bias would be both equal to zero. As is typical, MAE increases with the forecast horizon. MAE and Bias for the fleet of wind power resources are less due to offsetting errors. Across all time frames, the ISO-NE/DNV forecast is very good compared to industry standards, and monthly MAE is within the yearly performance targets.

# Wind Power Forecast Error Statistics: Medium and Long Term Forecasts Bias




Dashboard Indicator



Yearly Fleet  
Performance targets

Ideally, MAE and Bias would be both equal to zero. Positive bias means less windpower was actually available compared to forecast. Negative bias means more windpower was actually available compared to forecast. Across all time frames, the ISO-NE/DNV forecast compares well with industry standards, and monthly Bias is within yearly performance targets.

# Wind Power Forecast Error Statistics: Short Term Forecast MAE




Dashboard Indicator



Ideally, MAE and Bias would be both equal to zero. As is typical, MAE increases with the forecast horizon. MAE and Bias for the fleet of wind power resources are less due to offsetting errors. Across all time frames, the ISO-NE/DNV forecast is very good compared to industry standards, and monthly MAE is within the yearly performance targets.

# Wind Power Forecast Error Statistics: Short Term Forecast Bias



Dashboard Indicator



Yearly Fleet  
Performance targets


Ideally, MAE and Bias would be both equal to zero. Positive bias means less windpower was actually available compared to forecast. Negative bias means more windpower was actually available compared to forecast. Across all time frames, the ISO-NE/DNV forecast compares well with industry standards, and monthly Bias is within yearly performance.

# MARKET OPERATIONS





# Daily Average DA and RT ISO-NE Hub Prices and Input Fuel Prices: June 1-30, 2022




Underlying natural gas data furnished by:




Average price difference over this period (DA-RT): \$-3.27  
 Average price difference over this period ABS(DA-RT): \$9.58  
 Average percentage difference over this period ABS(DA-RT)/RT Average LMP: 13%  
 Gas price is average of Massachusetts delivery points

# DA LMPs Average by Zone & Hub, June 2022



# RT LMPs Average by Zone & Hub, June 2022





# Definitions

Day-Ahead Concept	Definition
Day-Ahead Load Obligation ( <b>DALO</b> )	The sum of day-ahead cleared load (including asset load, pump load, exports, and virtual purchases and excluding modeled transmission losses)
Day-Ahead Cleared Physical Energy	The sum of day-ahead cleared generation and cleared net imports



# Components of Cleared DA Supply and Demand

## – Last Three Months





Gen – Generation  
 Incs – Increment Offers  
 DA Fcst Load – Day-Ahead Forecast Load  
 DRR – Demand Response Resource



Fixed Dem – Fixed Demand  
 PrSens Dem – Price Sensitive Demand  
 Decs – Decrement Bids  
 Act Load – Actual Load



# Components of RT Supply and Demand – Last Three Months



# DAM Volumes as % of RT Actual Load (Forecasted Peak Hour)




Note: Forecasted peak hour for each day is reflected in the above values. Shown for each day (chart on right) and then averaged for each month (chart on left). 'DA Bid' categories reflect load assets only (Virtual and export bids not reflected.)




# DA vs. RT Load Obligation: June, This Year vs. Last Year

Monthly, Last 13 Months



Daily, This Year vs. Last Year




\*Hourly average values






# DA Volumes as % of Forecast in Peak Hour

Monthly, Last 13 Months




Daily: This Month



Note: There were **ten** system-level manual supplemental commitments for capacity required during the Reserve Adequacy Assessment (RAA) during the month.

# DA Cleared Physical Energy Difference from RT System Load at Forecasted Peak Hour\*




\*Negative values indicate DA Cleared Physical Energy value below its RT counterpart. Forecast peak hour reflected.




# DA vs. RT Net Interchange

## June 2021 vs. June 2022

Hourly Average by Day, Last Year




Hourly Average by Day, This Year



Net Interchange is the sum of daily imports minus the sum of daily exports  
Positive values are net imports

# Variable Production Cost of Natural Gas: Monthly




**Note:** Assumes proxy heat rate of 7,800,000 Btu/MWh for natural gas units.

Underlying natural gas data furnished by:



# Variable Production Cost of Natural Gas: Daily




**Note: Assumes proxy heat rate of 7,800,000 Btu/MWh for natural gas units.**

Underlying natural gas data furnished by:




# Hourly DA LMPs, June 1-30, 2022

Hourly Day-Ahead LMPs




# Hourly RT LMPs, June 1-30, 2022

Hourly Real-Time LMPs



# System Unit Availability



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	YTD
<b>2022</b>	93	93	93	77	73	94							87
<b>2021</b>	94	94	90	81	84	92	93	96	90	71	83	91	88
<b>2020</b>	95	96	93	85	86	91	95	97	91	74	80	89	89

Data as of 6/30/2022





# BACK-UP DETAIL



# DEMAND RESPONSE



# Capacity Supply Obligation (CSO) MW by Demand Resource Type for July 2022

Load Zone	ADCR*	On Peak	Seasonal Peak	Total
ME	91.1	209.3	0.0	300.4
NH	43.2	169.4	0.0	212.6
VT	40.7	127.9	0.0	168.6
CT	136.4	232.6	614.4	983.4
RI	40.5	341.3	0.0	381.9
SEMA	49.1	530.9	0.0	580.0
WCMA	90.6	559.1	35.2	684.9
NEMA	78.6	863.2	0.0	941.8
<b>Total</b>	<b>570.2</b>	<b>3,033.8</b>	<b>649.5</b>	<b>4,253.5</b>

\* Active Demand Capacity Resources

NOTE: CSO values include T&D loss factor (8%).

# NEW GENERATION



# New Generation Update


## *Based on Queue as of 07/01/22*

- Nineteen projects totaling 166 MW were added to the interconnection queue since the last update
  - They consist of one battery projects and eighteen solar with battery projects with in-service dates of 2023 through 2024
- Two projects were withdrawn and two went commercial
- In total, 354 generation projects are currently being tracked by the ISO, totaling approximately 33,864 MW



# Actual and Projected Annual Capacity Additions

## By Supply Fuel Type and Demand Resource Type



	2022	2023	2024	2025	2026	2027	2028	Total MW	% of Total <sup>1</sup>
Other Renewables	129	0	0	0	0	0	0	129	0.4
Battery	305	2,272	2,841	2,316	634	242	0	8,610	26.1
Solar <sup>2</sup>	2,383	1,175	1,213	654	831	0	0	6,256	19.0
Wind	24	1,752	1,556	2,645	5,203	5,599	0	16,779	50.9
Natural Gas/Oil <sup>3</sup>	151	0	672	0	0	0	0	823	2.5
Natural Gas	67	0	0	0	0	0	0	67	0.2
Demand Response - Passive	380	-28	-114	0	0	0	0	238	0.7
Demand Response - Active	62	-94	86	0	0	0	0	54	0.2
<b>Totals</b>	<b>3,501</b>	<b>5,077</b>	<b>6,254</b>	<b>5,615</b>	<b>6,668</b>	<b>5,841</b>	<b>0</b>	<b>32,956</b>	<b>100.0</b>


<sup>1</sup> Sum may not equal 100% due to rounding

<sup>2</sup> This category includes both solar-only, and co-located solar and battery projects

<sup>3</sup> The projects in this category are dual fuel, with either gas or oil as the primary fuel

- DR reflects changes from the initial FCM Capacity Supply Obligations in 2010-11

# Actual and Projected Annual Generator Capacity Additions By State



	2022	2023	2024	2025	2026	2027	2028	Total MW	% of Total <sup>1</sup>
Vermont	40	0	50	0	0	0	0	90	0.3
Rhode Island	502	236	704	0	91	0	0	1,533	4.7
New Hampshire	266	164	20	385	0	0	0	835	2.6
Maine	910	1,123	597	737	2,328	0	0	5,695	17.4
Massachusetts	1,001	3,156	3,462	4,049	2,966	3,441	0	18,075	55.3
Connecticut	340	520	1,449	444	1,283	2,400	0	6,436	19.7
Totals	3,059	5,199	6,282	5,615	6,668	5,841	0	32,664	100.0

<sup>1</sup> Sum may not equal 100% due to rounding

# New Generation Projection

## *By Fuel Type*

Unit Type	Total		Green		Yellow	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Biomass/Wood Waste	0	0	0	0	0	0
Battery Storage	59	8,610	0	0	59	8,610
Fuel Cell	2	30	0	0	2	30
Hydro	3	99	2	71	1	28
Natural Gas	7	67	0	0	7	67
Natural Gas/Oil	5	823	1	62	4	761
Nuclear	0	0	0	0	0	0
Solar	250	6,256	23	242	227	6,014
Wind	28	17,979	1	20	27	17,959
Total	354	33,864	27	395	327	33,469

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel
- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications



# New Generation Projection

## *By Operating Type*

Operating Type	Total		Green		Yellow	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Baseload	5	70	1	5	4	65
Intermediate	7	804	0	0	7	804
Peaker	314	15,011	25	370	289	14,641
Wind Turbine	28	17,979	1	20	27	17,959
Total	354	33,864	27	395	327	33,469

- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications

# New Generation Projection

## *By Operating Type and Fuel Type*

Unit Type	Total		Baseload		Intermediate		Peaker		Wind Turbine	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Biomass/Wood Waste	0	0	0	0	0	0	0	0	0	0
Battery Storage	59	8,610	0	0	0	0	59	8,610	0	0
Fuel Cell	2	30	2	30	0	0	0	0	0	0
Hydro	3	99	2	33	0	0	1	66	0	0
Natural Gas	7	67	1	7	3	43	3	17	0	0
Natural Gas/Oil	5	823	0	0	4	761	1	62	0	0
Nuclear	0	0	0	0	0	0	0	0	0	0
Solar	250	6,256	0	0	0	0	250	6,256	0	0
Wind	28	17,979	0	0	0	0	0	0	28	17,979
Total	354	33,864	5	70	7	804	314	15,011	28	17,979

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel

# FORWARD CAPACITY MARKET



# Capacity Supply Obligation FCA 13

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	685.554	683.116	-2.438	658.659	-24.457	609.826	-48.833
	Passive Demand	3,354.69	3,407.507	52.817	3,450.899	43.392	3,512.604	61.705
Demand Total		4,040.244	4,090.623	50.38	4,109.558	18.935	4,122.43	12.872
Generator	Non-Intermittent	28,586.498	27,868.341	-718.157	28,105.411	237.07	27,426.242	-679.169
	Intermittent	1,024.792	901.672	-123.12	896.285	-5.387	778.962	-117.323
Generator Total		2,9611.29	28,770.013	-841.28	29,001.696	231.683	28,205.204	-796.492
Import Total		1,187.69	1,292.41	104.72	1,292.41	0	1,115.22	-177.19
Grand Total*		34,839.224	34,153.046	-686.18	34,403.664	250.618	33,442.854	-960.81
Net ICR (NICR)		33,750	32,465	-1,285	32,765	300	31,590	-1,175

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.

ARA – Annual Reconfiguration Auction  
CSO – Capacity Supply Obligation

FCA – Forward Capacity Auction  
ICR – Installed Capacity Requirement

ISO-NE PUBLIC

# Capacity Supply Obligation FCA 14

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	592.043	688.07	96.027				
	Passive Demand	3,327.071	3,327.932	0.861				
Demand Total		3,919.114	4,016.002	96.888				
Generator	Non-Intermittent	27,816.902	28,275.143	458.241				
	Intermittent	1,160.916	1,128.446	-32.47				
Generator Total		28,977.818	29,403.589	425.771				
Import Total		1,058.72	1,058.72	0				
Grand Total*		33,955.652	34,478.311	522.661				
Net ICR (NICR)		32,490	32,980	490				

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 15

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	677.673	673.401	-4.272				
	Passive Demand	3,212.865	3,211.403	-1.462				
Demand Total		3,890.538	3,884.804	-5.734				
Generator	Non-Intermittent	28,154.203	27,714.778	-439.425				
	Intermittent	1,089.265	1,073.794	-15.471				
Generator Total		29,243.468	28,788.572	-454.896				
Import Total		1,487.059	1297.132	-189.927				
Grand Total*		34,621.065	33,970.508	-650.557				
Net ICR (NICR)		33,270	31,775	-1,495				

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 16

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	765.35						
	Passive Demand	2,557.256						
Demand Total		3,322.606						
Generator	Non-Intermittent	26,805.003						
	Intermittent	1,178.933						
Generator Total		27,983.936						
Import Total		1,503.842						
Grand Total*		32,810.384						
Net ICR (NICR)		31,645						

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond bilaterals and reconfiguration auction may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2015-2020 CCP Monthly Capacity Supply Obligation Changes report on the ISO New England website.

# Active/Passive Demand Response

## *CSO Totals by Commitment Period*

Commitment Period	Active/Passive	Existing	New	Grand Total
2019-20	Active	357.221	20.304	377.525
	Passive	2,018.20	350.43	2,368.63
	<b>Grand Total</b>	<b>2,375.422</b>	<b>370.734</b>	<b>2,746.156</b>
2020-21	Active	334.634	85.294	419.928
	Passive	2,236.73	554.292	2,791.02
	<b>Grand Total</b>	<b>2,571.361</b>	<b>639.586</b>	<b>3,210.947</b>
2021-22	Active	480.941	143.504	624.445
	Passive	2,604.79	370.568	2,975.36
	<b>Grand Total</b>	<b>3,085.734</b>	<b>514.072</b>	<b>3,599.806</b>
2022-23	Active	598.376	87.178	685.554
	Passive	2,788.33	566.363	3,354.69
	<b>Grand Total</b>	<b>3,386.703</b>	<b>653.541</b>	<b>4,040.244</b>
2023-24	Active	560.55	31.493	592.043
	Passive	3,035.51	291.565	3,327.07
	<b>Grand Total</b>	<b>3,596.056</b>	<b>323.058</b>	<b>3,919.114</b>
2024-25	Active	674.153	3.520	677.673
	Passive	3,046.064	166.801	3,212.865
	<b>Grand Total</b>	<b>3,720.217</b>	<b>170.321</b>	<b>3,890.538</b>
2025-26	Active	664.01	101.34	765.35
	Passive	2,428.638	128.618	2557.256
	<b>Grand Total</b>	<b>3,092.648</b>	<b>229.958</b>	<b>3,322.606</b>



# RELIABILITY COSTS – NET COMMITMENT PERIOD COMPENSATION (NCPC) OPERATING COSTS



# What are Daily NCPC Payments?

- Payments made to resources whose commitment and dispatch by ISO-NE resulted in a shortfall between the resource's offered value in the Energy and Regulation Markets and the revenue earned from output during the day
- Typically, this is the result of some out-of-merit operation of resources occurring in order to protect the overall resource adequacy and transmission security of specific locations or of the entire control area
- NCPC payments are intended to make a resource that follows the ISO's operating instructions "no worse off" financially than the best alternative generation schedule



# Definitions


1 <sup>st</sup> Contingency NCPC Payments	Reliability costs paid to eligible resources that are providing first contingency (1stC) protection (including low voltage, system operating reserve, and load serving) either system-wide or locally
2 <sup>nd</sup> Contingency NCPC Payments	Reliability costs paid to resources providing capacity in constrained areas to respond to a local second contingency. They are committed based on 2 <sup>nd</sup> Contingency (2ndC) protocols, and are also known as Local Second Contingency Protection Resources (LSCPR)
Voltage NCPC Payments	Reliability costs paid to resources operated by ISO-NE to provide voltage support or control in specific locations
Distribution NCPC Payments	Reliability costs paid to units dispatched at the request of local transmission providers for purpose of managing constraints on the low voltage (distribution) system. These requirements are not modeled in the DA Market software
OATT	Open Access Transmission Tariff

# Charge Allocation Key


Allocation Category	Market / OATT	Allocation
System 1 <sup>st</sup> Contingency	Market	DA 1 <sup>st</sup> C (excluding at external nodes) is allocated to system DALO. RT 1 <sup>st</sup> C (at all locations) is allocated to System 'Daily Deviations'. Daily Deviations = sum of(generator deviations, load deviations, generation obligation deviations at external nodes, increment offer deviations)
External DA 1 <sup>st</sup> Contingency	Market	DA 1 <sup>st</sup> C at external nodes (from imports, exports, Incs and Decs) are allocated to activity at the specific external node or interface involved
Zonal 2 <sup>nd</sup> Contingency	Market	DA and RT 2 <sup>nd</sup> C NCPC are allocated to load obligation in the Reliability Region (zone) served
System Low Voltage	OATT	(Low) Voltage Support NCPC is allocated to system Regional Network Load and Open Access Same-Time Information Service (OASIS) reservations
Zonal High Voltage	OATT	High Voltage Control NCPC is allocated to zonal Regional Network Load
Distribution - PTO	OATT	Distribution NCPC is allocated to the specific Participant Transmission Owner (PTO) requesting the service
System – Other	Market	Includes GPA, Economic Generator/DARD Posturing, Dispatch Lost Opportunity Cost (DLOC), and Rapid Response Pricing (RRP) Opportunity Cost NCPC (allocated to RTLO); and Min Generation Emergency NCPC (allocated to RTGO).

# Year-Over-Year Total NCPC Dollars and Energy

NCPC Dollars





NCPC Energy\*



\* NCPC Energy GWh reflect the DA and/or RT economic minimum loadings of all units receiving DA or RT NCPC credits (except for DLOC, RRP, or posturing NCPC), assessed during hours in which they are NCPC-eligible. Scheduled MW for external transactions receiving NCPC are also reflected. All NCPC components (1<sup>st</sup> Contingency, 2<sup>nd</sup> Contingency, Voltage, and RT Distribution) are reflected.




# DA and RT NCPC Charges




# NCPC Charges by Type

Jun-22 Total = \$2.99 M




1<sup>st</sup> C – First Contingency  
2<sup>nd</sup> C – Second Contingency  
Distrib – Distribution  
Voltage – Voltage

Last 13 Months





# Daily NCPC Charges by Type







# NCPC Charges by Allocation



Note: 'System Other' includes, as applicable: Resource Economic Posturing, GPA, Min Gen Emergency, Dispatch Lost Opportunity Cost (DLOC), and Rapid Response Pricing (RRP) Opportunity Cost credits.




# RT First Contingency Charges by Deviation Type




DRR – Demand Response Resource deviations  
Gen – Generator deviations  
Inc – Increment Offer deviations  
Import – Import deviations  
Load – Load obligation deviations




# LSCPR Charges by Reliability Region




# NCPC Charges for Voltage Support and High Voltage Control




# NCPC Charges by Type



# NCPC Charges as Percent of Energy Market




# First Contingency NCPC Charges



**Note:** Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market



# Second Contingency NCPC Charges




**Note:** Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market





# Voltage and Distribution NCPC Charges



**Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market**



# DA vs. RT Pricing

## The following slides outline:

- This month vs. prior year's average LMPs and fuel costs
- Reserve Market results
- DA cleared load vs. RT load
- Zonal and total incs and decs
- Self-schedules
- DA vs. RT net interchange




# DA vs. RT LMPs (\$/MWh)

## Arithmetic Average

Year 2020	NEMA	CT	ME	NH	VT	RI	SEMA	WCMA	Hub
Day-Ahead	\$23.62	\$22.59	\$23.27	\$23.50	\$22.76	\$23.27	\$23.57	\$23.30	\$23.32
Real-Time	\$23.62	\$22.91	\$23.23	\$23.54	\$22.90	\$23.29	\$23.56	\$23.37	\$23.38
RT Delta %	0.0%	1.4%	-0.2%	0.2%	0.6%	0.1%	-0.1%	0.3%	0.3%
Year 2021	NEMA	CT	ME	NH	VT	RI	SEMA	WCMA	Hub
Day-Ahead	\$46.54	\$44.60	\$45.52	\$46.27	\$45.05	\$45.88	\$46.38	\$45.91	\$45.92
Real-Time	\$45.25	\$43.97	\$44.28	\$45.10	\$44.15	\$44.61	\$45.09	\$44.85	\$44.84
RT Delta %	-2.8%	-1.4%	-2.7%	-2.5%	-2.0%	-2.8%	-2.8%	-2.3%	-2.3%

June-21	NEMA	CT	ME	NH	VT	RI	SEMA	WCMA	Hub
Day-Ahead	\$37.41	\$36.45	\$36.66	\$37.31	\$36.86	\$36.82	\$37.12	\$37.14	\$37.10
Real-Time	\$36.17	\$35.48	\$35.47	\$36.17	\$35.78	\$35.56	\$35.89	\$35.89	\$35.82
RT Delta %	-3.3%	-2.7%	-3.3%	-3.1%	-2.9%	-3.4%	-3.3%	-3.4%	-3.4%
June-22	NEMA	CT	ME	NH	VT	RI	SEMA	WCMA	Hub
Day-Ahead	\$69.15	\$67.48	\$68.32	\$69.08	\$67.80	\$68.11	\$68.71	\$68.58	\$68.43
Real-Time	\$72.50	\$71.03	\$71.49	\$72.31	\$70.82	\$71.43	\$72.04	\$71.86	\$71.71
RT Delta %	4.8%	5.3%	4.6%	4.7%	4.5%	4.9%	4.8%	4.8%	4.8%
Annual Diff.	NEMA	CT	ME	NH	VT	RI	SEMA	WCMA	Hub
Yr over Yr DA	84.9%	85.2%	86.3%	85.1%	83.9%	85.0%	85.1%	84.7%	84.5%
Yr over Yr RT	100.4%	100.2%	101.5%	99.9%	97.9%	100.9%	100.7%	100.2%	100.2%


# Monthly Average Fuel Price and RT Hub LMP Indexes



Underlying natural gas data furnished by:



# Monthly Average Fuel Price and RT Hub LMP




Underlying natural gas data furnished by:




# New England, NY, and PJM Hourly Average Real Time Prices by Month

Monthly, Last 13 Months



\*Note: Hourly average prices are shown.


Daily: This Month




\*Note: Hourly average prices are shown.

# New England, NY, and PJM Average Peak Hour Real Time Prices

Monthly, Last 13 Months



Daily: This Month



\*Forecasted New England daily peak hours reflected

# Reserve Market Results – June 2022


- Maximum potential Forward Reserve Market payments of \$11.9M were reduced by credit reductions of \$76K, failure-to-reserve penalties of \$128K and failure-to-activate penalties of \$187, resulting in a net payout of \$11.7M or 98% of maximum
  - Rest of System: \$8.56M/8.74M (98%)
  - Southwest Connecticut: \$0.04M/0.05M (98%)
  - Connecticut: \$3.02M/3.04M (99%)
  - NEMA: \$0.1M/0.1M (100%)
- \$1.1M total Real-Time credits were reduced by \$455K in Forward Reserve Energy Obligation Charges for a net of \$675K in Real-Time Reserve payments
  - Rest of System: 250 hours, \$381K
  - Southwest Connecticut: 250 hours, \$162K
  - Connecticut: 250 hours, \$78K
  - NEMA: 250 hours, \$55K

Note: “Failure to reserve” results in both credit reductions and penalties in the Locational Forward Reserve Market. While this summary reports performance by location, there were no locational requirements in effect for the current Forward Reserve auction period.







# LFRM Charges to Load by Load Zone (\$)




# Zonal Increment Offers and Cleared Amounts



# Zonal Decrement Bids and Cleared Amounts




# Total Increment Offers and Decrement Bids



Data excludes nodal offers and bids

# Dispatchable vs. Non-Dispatchable Generation



\* Dispatchable MWh here are defined to be all generation output that is not self-committed ('must run') by the customer.



# REGIONAL SYSTEM PLAN (RSP)



# Planning Advisory Committee (PAC)

- July 20 PAC Meeting Agenda Topics\*
  - Asset Condition Projects
    - A-1 & B-2 69 kV Line Asset Condition Project (National Grid)
    - Royalston Breaker Addition Chestnut Hill #702 Substation Asset Replacements (National Grid)
    - G-185S & L-190 Asset Condition Upgrades (National Grid)
    - 115 kV K-137 and L-138W Lines Pilot Protection Schemes (National Grid)
    - 115 kV A-127, B-128 and Z-126 Lines Pilot Protection Schemes, Webster Street and New Stafford Street Substation (National Grid)
  - Representative NICR and Operable Capacity Analysis
  - 2050 Transmission Study: Updated Results and Approximate Frequency of Overloads
  - NERC TPL-007-4 Benchmark and Supplemental Geomagnetic Disturbance 2026 Needs Assessment

\* Agenda topics are subject to change. Visit <https://www.iso-ne.com/committees/planning/planning-advisory> for the latest PAC agendas.



# Transmission Planning for the Clean Energy Transition (TPCET)

- On 9/24/20 the ISO initiated discussions with the PAC about proposed refinements to transmission planning study assumptions that better reflect long-term trends, such as increased amounts of distributed-energy resources (primarily solar PV), offshore wind generation, and battery energy storage
- A follow-up presentation at the 11/19/20, 12/16/20, and 1/21/21 PAC meetings outlined a proposal for a pilot study, with the following goals:
  - Explore transmission reliability concerns that may result from various system conditions possible by 2030
  - Quantify trade-offs necessary between transmission system reliability/flexibility and transmission investment cost
  - Inform future discussions on transmission planning study assumptions
- Results were discussed at the 6/16/21, 7/22/21, and 8/18/21 PAC meetings
- The ISO published final revisions to the Transmission Planning Technical Guide reflecting these changes on 9/30/21
- CEI supplement to the PAC presentations was released on 10/5/21
- The final TPCET Pilot Study Report was posted to the PAC website on 1/14/22
- Status updates on ongoing transient stability modeling and performance criteria were discussed at the 4/28/22, 5/18/22, and 6/15/22 PAC meetings



# 2050 Transmission Study

- A meeting with the states was held on 10/15/21 to review the draft study scope
- The draft study scope was discussed with the PAC on 11/17/21
- Written stakeholder comments were due on 12/2/21
- ISO worked with NESCOE to address the comments and finalized the scope on 12/22/21
- ISO provided initial results at the 3/16/22 PAC meeting
- Sensitivity results, as well as a high-level approach to solutions development, were discussed at the 4/28/22 PAC meeting



# Economic Studies

- 2020 Economic Study Request
  - Study proponent is National Grid
  - Final report was posted on June 10
- 2021 Economic Study Request
  - Also known as Future Grid Reliability Study – Phase 1 (FGRS)
  - Study proponent is NEPOOL
  - Gaps, key takeaways, and lessons learned were presented at the June 15 PAC meeting
  - Draft report was posted on June 15
- Economic Planning for the Clean Energy Transition Pilot Study
  - New effort to review all assumptions in economic planning and perform a test study consistent with the proposed changes to the Tariff
  - Initial scope of work presented at the April PAC meeting and the next presentation on input assumptions is expected at the August PAC meeting



# Future Grid Reliability Study (FGRS)


- Phase 1
  - Studies include: Production Cost Simulations; Ancillary Services Simulations; Resource Adequacy Screen; and Probabilistic Resource Availability Analysis
  - Framework Document and supporting assumptions table, which describe study scenarios and objectives, have been developed by stakeholders
  - Phase 1 work was submitted as the only 2021 Economic Study
- Phase 2
  - Studies include: Revenue Sufficiency Analysis and Transmission Security
  - Studies will be delayed as the Pathways and 2050 Transmission studies are performed
  - Scope expected to be shared with stakeholders in the 2<sup>nd</sup> half of 2022



# New England Power System Carbon Emissions

*CO<sub>2</sub> emissions Up 11% year to year, reflects January oil-fired generation spike*


## 2021 vs. 2022 New England Power System Estimated Carbon Dioxide (CO<sub>2</sub>) Emissions



Data as of 6/26/22

RGGI – Regional Greenhouse Gas Initiative

## RGGI Allowance Prices Affected by Factors External to New England




- 6/28/22: RGGI allowance spot price - \$14.00 per allowance (1 allowance = 1 short ton CO<sub>2</sub>)
- 6/1/22 56<sup>th</sup> RGGI auction cleared at \$13.90
  - 97 million allowances will be auctioned in 2022
  - 192 million allowances already in circulation
- Coal-fired retirements in PJM RGGI states during 2022 projected to lower future demand for allowances

# Massachusetts CO<sub>2</sub> Generator Emissions Cap

## Uptick in 2022 Estimated Emissions Under CO<sub>2</sub> Cap

- 6/27/22: 2022 estimated GWSA CO<sub>2</sub> emissions range between 2.6 and 3.1 MMT
  - 33% to 39% of the 8.06 MMT 2022 cap
- 6/10/22 GWSA auction cleared at \$9.75; 1.20 million 2022 vintage allowances sold
  - 2022 RGGI allowance spot price at \$14.05 per metric ton
  - 0.39 million 2023 vintage GWSA allowances were also offered, clearing at \$4.00
- 3/18/22 GWSA auction cleared at \$0.50 per metric ton of CO<sub>2</sub> for 1.61 million 2022 vintage GWSA allowances
- IMM estimated compliance costs by fuel type (based on average GWSA emission/heat rates):
  - No. 2 fuel oil - \$8.54/MWh
  - No. 6 fuel oil - \$8.29/MWh
  - Natural gas - \$2.39/MWh

## 2020-2022 Estimated Monthly Emissions (Thousand Metric tons)



GWSA – Global Warming Solutions Act  
MMT – Million Metric Tons

Sources: ISO-NE (estimated emissions); EPA (actual emissions)

# RSP Project Stage Descriptions

Stage	Description
1	Planning and Preparation of Project Configuration
2	Pre-construction (e.g., material ordering, project scheduling)
3	Construction in Progress
4	In Service

Note: The listings in this section focus on major transmission line construction and rebuilding.



# Greater Boston Projects

*Status as of 6/29/2022*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1213, 1220, 1365	Install new 345 kV line from Scobie to Tewksbury	Dec-17	4
1527, 1528	Reconductor the Y-151 115 kV line from Dracut Junction to Power Street	Apr-17	4
1212, 1549	Reconductor the M-139 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury	May-17	4
1549	Reconductor the N-140 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury	May-17	4
1260	Reconductor the F-158N 115 kV line from Wakefield Junction to Maplewood and associated work at Maplewood	Dec-15	4
1550	Reconductor the F-158S 115 kV line from Maplewood to Everett	Jun-19	4
1551, 1552	Install new 345 kV cable from Woburn to Wakefield Junction, install two new 160 MVAR variable shunt reactors and associated work at Wakefield Junction and Woburn*	May-23	3*
1329	Refurbish X-24 69 kV line from Millbury to Northboro Road	Dec-15	4
1327	Reconductor W-23W 69 kV line from Woodside to Northboro Road	Jun-19	4

\* Substation portion of the project is a Present Stage status 4

# Greater Boston Projects, cont.

## *Status as of 6/29/2022*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1330	Separate X-24 and E-157W DCT	Dec-18	4
1363	Separate Q-169 and F-158N DCT	Dec-15	4
1637, 1640	Reconductor M-139/211-503 and N-140/211-504 115 kV lines from Pinehurst to North Woburn tap	May-17	4
1516	Install new 115 kV station at Sharon to segment three 115 kV lines from West Walpole to Holbrook	Sep-20	4
965	Install third 115 kV line from West Walpole to Holbrook	Sep-20	4
1558	Install new 345 kV breaker in series with the 104 breaker at Stoughton	May-16	4
1199	Install new 230/115 kV autotransformer at Sudbury and loop the 282-602 230 kV line in and out of the new 230 kV switchyard at Sudbury	Dec-17	4
1335	Install a new 115 kV line from Sudbury to Hudson	Dec-23	2



# Greater Boston Projects, cont.

*Status as of 6/29/2022*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1336	Replace 345/115 kV autotransformer, 345 kV breakers, and 115 kV switchgear at Woburn	Dec-19	4
1553	Install a 345 kV breaker in series with breaker 104 at Woburn	Jun-17	4
1337	Reconfigure Waltham by relocating PARs, 282-507 line, and a breaker	Dec-17	4
1339	Upgrade 533-508 115 kV line from Lexington to Hartwell and associated work at the stations	Aug-16	4
1521	Install a new 115 kV 54 MVAR capacitor bank at Newton	Dec-16	4
1522	Install a new 115 kV 36.7 MVAR capacitor bank at Sudbury	May-17	4
1352	Install a second Mystic 345/115 kV autotransformer and reconfigure the bus	May-19	4
1353	Install a 115 kV breaker on the East bus at K Street	Jun-16	4
1354, 1738	Install 115 kV cable from Mystic to Chelsea and upgrade Chelsea 115 kV station to BPS standards	Jul-21	4
1355	Split 110-522 and 240-510 DCT from Baker Street to Needham for a portion of the way and install a 115 kV cable for the rest of the way	Mar-21	4

# Greater Boston Projects, cont.

*Status as of 6/29/2022*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1356	Install a second 115 kV cable from Mystic to Woburn to create a bifurcated 211-514 line	Dec-22	3
1357	Open lines 329-510/511 and 250-516/517 at Mystic and Chatham, respectively. Operate K Street as a normally closed station.	May-19	4
1518	Upgrade Kingston to create a second normally closed 115 kV bus tie and reconfigure the 345 kV switchyard	Mar-19	4
1519	Relocate the Chelsea capacitor bank to the 128-518 termination postion	Dec-16	4

# Greater Boston Projects, cont.

*Status as of 6/29/2022*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1520	Upgrade North Cambridge to mitigate 115 kV 5 and 10 stuck breaker contingencies	Dec-17	4
1643	Install a 200 MVAR STATCOM at Coopers Mills	Nov-18	4
1341, 1645	Install a 115 kV 36.7 MVAR capacitor bank at Hartwell	May-17	4
1646	Install a 345 kV 160 MVAR shunt reactor at K Street	Dec-19	4
1647	Install a 115 kV breaker in series with the 5 breaker at Framingham	Mar-17	4
1554	Install a 115 kV breaker in series with the 29 breaker at K Street	Apr-17	4

# SEMA/RI Reliability Projects

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/Actual In-Service	Present Stage
1714	Construct a new 115 kV GIS switching station (Grand Army) which includes remote terminal station work at Brayton Point and Somerset substations, and the looping in of the E-183E, F-184, X3, and W4 lines	Oct-20	4
1742	Conduct remote terminal station work at the Wampanoag and Pawtucket substations for the new Grand Army GIS switching station	Oct-20	4
1715	Install upgrades at Brayton Point substation which include a new 115 kV breaker, new 345/115 kV transformer, and upgrades to E183E, F184 station equipment	Oct-20	4
1716	Increase clearances on E-183E & F-184 lines between Brayton Point and Grand Army substations	Nov-19	4
1717	Separate the X3/W4 DCT and reconductor the X3 and W4 lines between Somerset and Grand Army substations; reconfigure Y2 and Z1 lines	Nov-19	4

# SEMA/RI Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1718	Add 115 kV circuit breaker at Robinson Ave substation and re-terminate the Q10 line	Mar-22	4
1719	Install 45.0 MVAR capacitor bank at Berry Street substation	Cancelled*	N/A
1720	Separate the N12/M13 DCT and reconductor the N12 and M13 between Somerset and Bell Rock substations	May-25	2
1721	Reconfigure Bell Rock to breaker-and-a-half station, split the M13 line at Bell Rock substation, and terminate 114 line at Bell Rock; install a new breaker in series with N12/D21 tie breaker, upgrade D21 line switch, and install a 37.5 MVAR capacitor	Dec-23	3
1722	Extend the Line 114 from the Dartmouth town line (Eversource-National Grid border) to Bell Rock substation	Dec-24	2
1723	Reconductor L14 and M13 lines from Bell Rock substation to Bates Tap	Cancelled*	N/A

\*Cancelled per ISO-NE PAC presentation on August 27, 2020

# SEMA/RI Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1725	Build a new 115 kV line from Bourne to West Barnstable substations which includes associated terminal work	Dec-23	1
1726	Separate the 135/122 DCT from West Barnstable to Barnstable substations	Dec-21	4
1727	Retire the Barnstable SPS	Nov-21	4
1728	Build a new 115 kV line from Carver to Kingston substations and add a new Carver terminal	Jun-23	3
1729	Install a new bay position at Kingston substation to accommodate new 115 kV line	Jun-23	3
1730	Extend the 114 line from the Eversource/National Grid border to the Industrial Park Tap	Dec-24	2

# SEMA/RI Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/Actual In-Service	Present Stage
1731	Install 35.3 MVAR capacitors at High Hill and Wing Lane substations	Dec-21	4
1732	Loop the 201-502 line into the Medway substation to form the 201-502N and 201-502S lines	Dec-25	3
1733	Separate the 325/344 DCT lines from West Medway to West Walpole substations	Cancelled**	N/A
1734	Reconductor and upgrade the 112 Line from the Tremont substation to the Industrial Tap	Jun-18	4
1736	Reconductor the 108 line from Bourne substation to Horse Pond Tap*	Oct-18	4
1737	Replace disconnect switches on 323 line at West Medway substation and replace 8 line structures	Aug-20	4

\* Does not include the reconductoring work over the Cape Cod canal

\*\* Cancelled per ISO-NE PAC presentation on August 27, 2020



# SEMA/RI Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1741	Rebuild the Middleborough Gas and Electric portion of the E1 line from Bridgewater to Middleborough	Apr-19	4
1782	Reconductor the J16S line	May 22	4
1724	Replace the Kent County 345/115 kV transformer	Mar-22	4
1789	West Medway 345 kV circuit breaker upgrades	Apr-21	4
1790	Medway 115 kV circuit breaker replacements	Nov-20	4



# Eastern CT Reliability Projects

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1815	Reconductor the L190-4 and L190-5 line sections	Dec-24	2
1850	Install a second 345/115 kV autotransformer (4X) and one 345 kV breaker at Card substation	Mar-23	2
1851	Upgrade Card 115 kV to BPS standards	Mar-23	2
1852	Install one 115 kV circuit breaker in series with Card substation 4T	Mar-23	2
1853	Convert Gales Ferry substation from 69 kV to 115 kV	Dec-23	2
1854	Rebuild the 100 Line from Montville to Gales Ferry to allow operation at 115 kV	Dec-22	3



# Eastern CT Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1855	Re-terminate the 100 Line at Montville station and associated work. Energize the 100 Line at 115 kV	Dec-23	2
1856	Rebuild 400-1 Line section to allow operation at 115 kV (Tunnel to Ledyard Jct.)	Dec-22	3
1857	Add one 115 kV circuit breaker and re-terminate the 400-1 line section into Tunnel substation. Energize 400 Line at 115 kV	Dec-23	3
1858	Rebuild 400-2 Line section to allow operation at 115 kV (Ledyard Jct. to Border Bus with CMEEC)	Dec-22	3
1859	Rebuild the 400-3 Line Section to allow operation at 115 kV (Gales Ferry to Ledyard Jct.)	Dec-22	3
1860	Install a 25.2 MVAR 115 kV capacitor and one capacitor breaker at Killingly	Dec-21	4

# Eastern CT Reliability Projects, cont.

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1861	Install one 345 kV series breaker with the Montville 1T	Nov-21	4
1862	Install a 50 MVAR synchronous condenser with two 115 kV breakers at Shunock	Dec-24	3
1863	Install a 1% series reactor with bypass switch at Mystic, CT on the 1465 Line	Mar-22	4
1864	Convert the 400-2 Line Section to 115 kV (Border Bus to Buddington), convert Buddington to 115 kV	Dec-23	3



# Boston Area Optimized Solution Projects

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Boston area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1874	Install two 11.9 ohm series reactors at North Cambridge Station on Lines 346 and 365	Dec-21	4
1875	Install a direct transfer trip (DTT) scheme between Ward Hill and West Amesbury Substations for Line 394	Apr-22	4
1876	Install one +/- 167 MVAR STATCOM at Tewksbury 345 kV Substation	Oct-23	3



# New Hampshire Solution Projects

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the New Hampshire area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1878	Install a +50/-25 MVAR synchronous condenser at N. Keene 115 kV Substation with a 115 kV breaker	Aug-23	2
1879	Install a +50/-25 MVAR synchronous condenser at Huckins Hill 115 kV Substation with a 115 kV breaker	Aug-23	2
1880	Install a +100/-50 MVAR synchronous condenser at Amherst 345 kV Substation with two 345 kV breakers	Dec-23	2
1881	Install two 50 MVAR capacitors on Line 363 near Seabrook Station with three 345 kV breakers	Oct-23	1



# Upper Maine Solution Projects

*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Upper Maine area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1882	Rebuild 21.7 miles of the existing 115 kV line Section 80 Highland – Coopers Mills 115 kV line	Dec-27	2
1883	Convert the Highland 115 kV substation to an eight breaker, breaker-and-a-half configuration with a bus connected 115/34.5 kV transformer	Dec-27	1
1884	Install a 15 MVAR capacitor at Belfast 115 kV substation	Dec-27	1
1885	Install a +50/-25 MVAR synchronous condenser at Highland 115 kV substation	Dec-27	1
1886	Install +50/-25 MVAR synchronous condenser at Boggy Brook 115 kV substation, and install a new 115 kV breaker to separate Line 67 from the proposed solution elements	Jun-24	2



# Upper Maine Solution Projects, cont.


*Status as of 6/29/2022*

*Project Benefit: Addresses system needs in the Upper Maine area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1887	Install 25 MVAR reactor at Boggy Brook 115 kV substation	Jun-24	2
1888	Install 10 MVAR reactor at Keene Road 115 kV substation	Jun-24	2
1889	Install three remotely monitored and controlled switches to split the existing Orrington reactors between the two Orrington 345/115 kV autotransformers	Dec-23	2



# Status of Tariff Studies as of July 1, 2022



## Generator Project Status


5 ETUs in Scoping, 2 in FS, 1 in SIS, 0 in OIS, 0 in FAC, 2 Negotiating IA, and 2 with Executed IA  
Transmission Service Requests needing study: 1 in Scoping

<https://irtt.iso-ne.com/external.aspx>



# What is in the Queue (as of July 1, 2022)

Storage Projects are proposed as stand-alone storage or as co-located with wind or solar projects



# OPERABLE CAPACITY ANALYSIS

*Summer 2022 Analysis*



# Summer 2022 Operable Capacity Analysis

50/50 Load Forecast (Reference)	September - 2022 <sup>2</sup> CSO (MW)	September - 2022 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,868	29,647
Active Demand Capacity Resource (+) <sup>5</sup>	559	446
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,115	1,115
Non Commercial Capacity (+)	129	129
Non Gas-fired Planned Outage MW (-)	791	1,151
Gas Generator Outages MW (-)	272	342
Allowance for Unplanned Outages (-) <sup>4</sup>	2,100	2,100
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	0	0
Net Capacity (NET OPCAP SUPPLY MW)	26,508	27,744
Peak Load Forecast MW(adjusted for Other Demand Resources) <sup>2</sup>	24,686	24,686
Operating Reserve Requirement MW	2,305	2,305
Operable Capacity Required (NET LOAD OBLIGATION MW)	26,991	26,991
Operable Capacity Margin	-483	753

<sup>1</sup>Operable Capacity is based on data as of **June 23, 2022** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **June 23, 2022**.

<sup>2</sup> Load forecast that is based on the 2022 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 10, 2022**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Summer 2022 Operable Capacity Analysis

90/10 Load Forecast	September - 2022 <sup>2</sup> CSO (MW)	September - 2022 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,868	29,647
Active Demand Capacity Resource (+) <sup>5</sup>	559	446
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,115	1,115
Non Commercial Capacity (+)	129	129
Non Gas-fired Planned Outage MW (-)	791	1,151
Gas Generator Outages MW (-)	272	342
Allowance for Unplanned Outages (-) <sup>4</sup>	2,100	2,100
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	0	0
Net Capacity (NET OPCAP SUPPLY MW)	26,508	27,744
Peak Load Forecast MW (adjusted for Other Demand Resources) <sup>2</sup>	26,416	26,416
Operating Reserve Requirement MW	2,305	2,305
Operable Capacity Required (NET LOAD OBLIGATION MW)	28,721	28,721
Operable Capacity Margin	-2,213	-977

<sup>1</sup> Operable Capacity is based on data as of **June 23, 2022** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **June 23, 2022**.

<sup>2</sup> Load forecast that is based on the 2022 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **September 10, 2022**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Summer 2022 Operable Capacity Analysis

## 50/50 Forecast (Reference)

### ISO-NE OPERABLE CAPACITY ANALYSIS

June 23, 2022 - 50-50 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during July, August and September.

Report created: 6/23/2022

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 50- 50PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 50- 50PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min Opcap Margin Flag	Season_Label
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
7/9/2022	27819	526	1103	20	225	0	2100	0	27143	24686	2305	26991	152	N	Summer 2022
7/16/2022	27819	526	1103	20	219	0	2100	0	27149	24686	2305	26991	158	N	Summer 2022
7/23/2022	27819	526	1103	20	106	0	2100	0	27262	24686	2305	26991	271	N	Summer 2022
7/30/2022	27871	559	1115	126	52	0	2100	0	27519	24686	2305	26991	528	N	Summer 2022
8/6/2022	27871	559	1115	126	82	0	2100	0	27489	24686	2305	26991	498	N	Summer 2022
8/13/2022	27871	559	1115	126	90	0	2100	0	27481	24686	2305	26991	490	N	Summer 2022
8/20/2022	27871	559	1115	126	88	0	2100	0	27483	24686	2305	26991	492	N	Summer 2022
8/27/2022	27871	559	1115	126	37	0	2100	0	27534	24686	2305	26991	543	N	Summer 2022
9/3/2022	27868	559	1115	129	43	0	2100	0	27528	24686	2305	26991	537	N	Summer 2022
9/10/2022	27868	559	1115	129	791	272	2100	0	26508	24686	2305	26991	-483	Y	Summer 2022

### Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply MW:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8-9)
- Peak Load Forecast MW:** Provided in the annual 2022 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

# Summer 2022 Operable Capacity Analysis

## 90/10 Forecast

### ISO-NE OPERABLE CAPACITY ANALYSIS

June 23, 2022 - 90/10 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during July, August and September.

Report created: 6/23/2022

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 90- 10PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 90- 10PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min Opcap Margin Flag	Season_Label
7/9/2022	27819	526	1103	20	225	0	2100	0	27143	26416	2305	28721	-1578	N	Summer 2022
7/16/2022	27819	526	1103	20	219	0	2100	0	27149	26416	2305	28721	-1572	N	Summer 2022
7/23/2022	27819	526	1103	20	106	0	2100	0	27262	26416	2305	28721	-1459	N	Summer 2022
7/30/2022	27871	559	1115	126	52	0	2100	0	27519	26416	2305	28721	-1202	N	Summer 2022
8/6/2022	27871	559	1115	126	82	0	2100	0	27489	26416	2305	28721	-1232	N	Summer 2022
8/13/2022	27871	559	1115	126	90	0	2100	0	27481	26416	2305	28721	-1240	N	Summer 2022
8/20/2022	27871	559	1115	126	88	0	2100	0	27483	26416	2305	28721	-1238	N	Summer 2022
8/27/2022	27871	559	1115	126	37	0	2100	0	27534	26416	2305	28721	-1187	N	Summer 2022
9/3/2022	27868	559	1115	129	43	0	2100	0	27528	26416	2305	28721	-1193	N	Summer 2022
9/10/2022	27868	559	1115	129	791	272	2100	0	26508	26416	2305	28721	-2213	Y	Summer 2022


### Column Definitions

- 1. CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- 2. CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- 3. External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- 4. Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- 5. CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
- 6. CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- 7. Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- 8. CSO Generation at Risk Due to Gas Supply Mw:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- 9. CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8-9)
- 10. Peak Load Forecast MW:** Provided in the annual 2022 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- 11. Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- 12. CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- 13. CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- 14. Operable Capacity Season Label:** Applicable season and year.
- 15. Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

\*Highlighted week is based on the week determined by the 50/50 Load Forecast Reference week


# Summer 2022 Operable Capacity Analysis

## 50/50 Forecast (Reference)



# Summer 2022 Operable Capacity Analysis

## 90/10 Forecast





# OPERABLE CAPACITY ANALYSIS

## *Appendix*



# Possible Relief Under OP4: Appendix A

OP 4 Action Number	Page 1 of 2 Action Description	Amount Assumed Obtainable Under OP 4 (MW)
1	Implement Power Caution and advise Resources with a CSO to prepare to provide capacity and notify "Settlement Only" generators with a CSO to monitor reserve pricing to meet those obligations. Begin to allow the depletion of 30-minute reserve.	0 <sup>1</sup>  600
2	Declare Energy Emergency Alert (EEA) Level 1 <sup>4</sup>	0
3	Voluntary Load Curtailment of Market Participants' facilities.	40 <sup>2</sup>
4	Implement Power Watch	0
5	Schedule Emergency Energy Transactions and arrange to purchase Control Area-to-Control Area Emergency	1,000
6	Voltage Reduction requiring > 10 minutes	125 <sup>3</sup>

## NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test.
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations



# Possible Relief Under OP4: Appendix A

OP 4 Action Number	Page 2 of 2 Action Description	Amount Assumed Obtainable Under OP 4 (MW)
7	Request generating resources not subject to a Capacity Supply Obligation to voluntary provide energy for reliability purposes	0
8	5% Voltage Reduction requiring 10 minutes or less	250 <sup>3</sup>
9	Transmission Customer Generation Not Contractually Available to Market Participants during a Capacity Deficiency.  Voluntary Load Curtailment by Large Industrial and Commercial Customers.	5  200 <sup>2</sup>
10	Radio and TV Appeals for Voluntary Load Curtailment Implement Power Warning	200 <sup>2</sup>
11	Request State Governors to Reinforce Power Warning Appeals.	100 <sup>2</sup>
Total		<b>2,520</b>

## NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test.
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations

